


PIPING SCHEMATIC

- NOTES:
1. ALL PIPING AND FITTINGS SHALL BE 3/4" SCH. 40 316 SS THREADED PIPING WITH PTFE SEALS UNLESS OTHERWISE REQUIRED BY COMPONENTS.
 2. ALL DIMENSIONS ARE IN INCHES AND ARE SHOWN FOR REFERENCE ONLY.
 3. (2) 3/4" SST BACK PRESSURE VALVES, P/N 1008797, ARE TO BE SHIPPED LOOSE FOR FIELD INSTALLATION BY OTHERS AT THE INJECTION POINT.
 4. (1) CONTROL PANEL PER DWG. 2007601065-300-303 TO BE SHIPPED LOOSE WITH THE SKID.

| REV | DATE | DESCRIPTION | BY | APPD | REVD |
|-----|----------|-------------------------------|-----|------|------|
| D | 06/08/09 | REVISED NOTES | GJS | | |
| C | 05/21/09 | REVISED PER CUSTOMER COMMENTS | GJS | | |

| REVISIONS | | | |
|--|------------|--|--------|
| CUSTOMER | | AMJ EQUIPMENT CORP. (CITY OF JUPITER) | |
| JOB No | 2007601065 | PURCHASE ORDER No | P02505 |
| TITLE P2_S2CA_316SSTh_NaOH GENERAL ARRANGEMENT | | | |

THIS DRAWING IS THE PROPERTY OF PROMINENT FLUID CONTROLS INC. AND SHALL NOT BE COPIED OR TRANSFERRED WITHOUT THE WRITTEN CONSENT OF PROMINENT FLUID CONTROLS INC.

| | | |
|------------------|---|---|
| ENGINEERS SEAL |  | |
| | PITTSBURGH, PA USA WWW.PROMINENT.US | |
| | PROMINENT FLUID CONTROLS LTD. 490 SOUTHGATE DRIVE. GUELPH, ONTARIO, CANADA N1H 6J3 TEL. 519 836 5692 FAX. 519 836 5226 | PROMINENT FLUID CONTROLS INC. RIDC PARK WEST 136 INDUSTRY DRIVE, PITTSBURGH P.A., USA. 15275 TEL. 412 787 2484 FAX. 412 787 0704 |
| | DESIGNED TAH | APPROVED |
| | DRAWN TAH | SCALE N.T.S. |
| CHECKED CRG | | DATE 02/05/08 |

| | |
|-----------------------------------|---------|
| MAXIMUM TESTING PRESSURE = | 150 PSI |
| MAXIMUM OPERATING PRESSURE = | 100 PSI |
| CHEMICAL SERVICE = NAOH-BLEND BOX | |

| | | | | | |
|--------|----------------|-----|---|------|-----|
| DWG No | 2007601065-204 | REV | D | PAGE | 1/1 |
|--------|----------------|-----|---|------|-----|