

ProMinent® Identcodes DULCOMETER® Instrumentation

DMT Transmitters Identcode Ordering System

| DMT | | Version: | | | | | | | | | | | |
|-----|---|---|--|---|---|---|---|---|---|---|---|---|---|
| | A | | | | | | | | | | | | |
| | | Type of Mounting: | | | | | | | | | | | |
| | | W | Wall mounted (also rail mounted) | | | | | | | | | | |
| | | S | Control panel installation ¹ | | | | | | | | | | |
| | | Logo: | | | | | | | | | | | |
| | | 0 | With ProMinent® logo | | | | | | | | | | |
| | | Electrical connection: | | | | | | | | | | | |
| | | 9 | Ring main 4-20 mA (two wire technology), operating voltage 16-40 V DC, nominal 24 V DC | | | | | | | | | | |
| | | 5 | PROFIBUS® DP, operating voltage 16 - 30 V DC, nominal 24 V DC (only if communication interface = PROFIBUS® DP) | | | | | | | | | | |
| | | Communication interface: | | | | | | | | | | | |
| | | 0 | None | | | | | | | | | | |
| | | 4 | PROFIBUS® DP (assembly type W only) | | | | | | | | | | |
| | | Measured variable 1: | | | | | | | | | | | |
| | | P | pH | | | | | | | | | | |
| | | R | Redox | | | | | | | | | | |
| | | T | Temperature | | | | | | | | | | |
| | | C | Chlorine | | | | | | | | | | |
| | | L | Conductivity | | | | | | | | | | |
| | | Measured variable 2 (Correcting value): | | | | | | | | | | | |
| | | 1 | Temperature Pt 1000 / Pt 100 | | | | | | | | | | |
| | | 0 | None (in the case of measured variable T) | | | | | | | | | | |
| | | Enclosure rating: | | | | | | | | | | | |
| | | 0 | Standard | | | | | | | | | | |
| | | Language: | | | | | | | | | | | |
| | | E | English | | | | | | | | | | |
| | | Presetting A, probe: | | | | | | | | | | | |
| | | 0 | Standard ProMinent® buffer solution pH 4-7-10 | | | | | | | | | | |
| | | Presetting B, probe: | | | | | | | | | | | |
| | | 0 | Autom. Temperature measurement (standard) | | | | | | | | | | |
| | | 1 | Manual temperature measurement | | | | | | | | | | |
| | | 2 | Autom./manual temperature measurement | | | | | | | | | | |
| | | 9 | No temperature measurement | | | | | | | | | | |
| | | Presetting C, output: | | | | | | | | | | | |
| | | 0 | Prop. Measured variable (standard) | | | | | | | | | | |
| | | 1 | Manual adjustable current value | | | | | | | | | | |
| | | 2 | Proportional or manual | | | | | | | | | | |
| | | 3 | Proportional or manual hold | | | | | | | | | | |
| | | 4 | 4 mA constant current | | | | | | | | | | |
| | | Presetting C: | | | | | | | | | | | |
| | | 0 | Standard | | | | | | | | | | |
| DMT | A | W | 0 | 9 | 0 | P | 1 | 0 | E | 0 | 0 | 0 | 0 |