


- NOTES:
1. ALL PIPING AND FITTINGS SHALL BE 1/2" SCH. 80 PVC SOCKET WELD WITH VITON SEALS UNLESS OTHERWISE REQUIRED BY COMPONENTS.
  2. 1/2" P.E. TUBING PROVIDED LOOSE WITH PCM PANEL.
  3. DIC ORDERED SEPERATELY WITH PCM PANEL.
  4. OPTIONAL POWER CORD AVAILABLE.
  5. ALL DIMENSIONS ARE IN INCHES AND ARE SHOWN FOR REFERENCE ONLY.



A	06-02-04	UPDATES PCM PANEL, CONVERTED TO SE		GJS					
0	06-17-99	FIRST ISSUE		DTH					
REV	DATE	DESCRIPTION		BY	APPD/REVD				
REVISIONS									
CUSTOMER									
PROMINENT FLUID CONTROLS, INC.									
JOB No		7740725		PURCHASE ORDER No					
TITLE									
PCM PANEL ASSEMBLY ENCLOSED GENERAL ARRANGEMENT									
THIS DRAWING IS THE PROPERTY OF PROMINENT FLUID CONTROLS LTD. AND SHALL NOT BE COPIED OR TRANSFERRED WITHOUT THE WRITTEN CONSENT OF PROMINENT FLUID CONTROLS LTD.									
ENGINEERS SEAL		<div><div><div><div></div><div>pfc</div><div>ProMinent</div></div></div><div><div>ProMinent®</div><div>THE PROMINENT GROUP OF COMPANIES</div></div></div>							
						PITTSBURGH, PA USA		WWW.PROMINENT.CC	
						PROMINENT FLUID CONTROLS LTD. 490 SOUTHGATE DRIVE. GUELPH, ONTARIO, CANADA N1H 6J3 TEL. 519 836 5692      FAX. 519 836 5226		PROMINENT FLUID CONTROLS LTD. RIDC PARK WEST 136 INDUSTRY DRIVE, PITTSBURGH P.A., USA. 15275 TEL. 412 787 2484      FAX. 412 787 0704	
						DESIGNED      DTH		APPROVED	
						DRAWN      DTH		SCALE      NTS	
CHECKED      RJB		DATE      06-17-99							
DWG No				REV	PAGE				
7740725-600				A	1/1				