



ISOMETRIC VIEW

- NOTES:
1. ALL PIPING AND FITTINGS SHALL BE 1/2" SCH. 80 SOCKET WELD UNLESS OTHERWISE REQUIRED BY COMPONENTS.
 2. ALL DIMENSIONS ARE IN INCHES AND ARE SHOWN FOR REFERENCE ONLY.
 3. QUANTITY OF (1) STIRRING MAGNET TO BE SHIPPED LOOSE WITH PANEL.

D	12/09/09	UPDATED WITH PARTS LIBRARY		ALS		
C	05/06/09	UPDATED SENSOR & TRANSDUCER P/N		CLW		
B	01/22/03	REVISED PIPING		CLW		
A	07/24/02	REVISED WIRING		CLW		
0	07/10/02	FIRST ISSUE		CLW		
REV	DATE	DESCRIPTION		BY	APPD	REVD
REVISIONS						
CUSTOMER		PROMINENT FLUID CONTROLS				
JOB No		7744836		PURCHASE ORDER No		
TITLE		FLUORIDE MONITOR PANEL MOUNT GENERAL ARRANGEMENT				
THIS DRAWING IS THE PROPERTY OF PROMINENT FLUID CONTROLS INC. AND SHALL NOT BE COPIED OR TRANSFERRED WITHOUT THE WRITTEN CONSENT OF PROMINENT FLUID CONTROLS INC.						
ENGINEERS SEAL		<div><div><div><div>ptc</div><div>ProMinent</div></div><div><div>ProMinent[®]</div><div>THE PROMINENT GROUP OF COMPANIES</div></div></div></div> <div><div>PITTSBURGH, PA USA</div><div>WWW.PROMINENT.US</div><div><div><div>PROMINENT FLUID CONTROLS LTD. 490 SOUTHGATE DRIVE. GUELPH, ONTARIO, CANADA N1H 6J3 TEL. 519 836 5692 FAX. 519 836 5226</div><div><div>PROMINENT FLUID CONTROLS INC. RIDC PARK WEST 136 INDUSTRY DRIVE, PITTSBURGH P.A., USA. 15275 TEL. 412 787 2484 FAX. 412 787 0704</div></div></div><div><div>DESIGNED</div><div>CLW</div><div>APPROVED</div></div><div><div>DRAWN</div><div>CLW</div><div>SCALE</div><div>N.T.S.</div></div><div><div>CHECKED</div><div>RJB</div><div>DATE</div><div>07/10/02</div></div></div></div>				
DWG No				REV		PAGE
7744836-200				D		1/1