







PIPING SCHEMATIC

NOTES:

- 1. ALL PIPING AND FITTINGS SHALL BE 1" SCH. 80 PVC SOCKET WELD WITH EPDM SEALS UNLESS OTHERWISE REQUIRED BY COMPONENTS.
- 2. COUPONS ARE NOT INCLUDED.
- 3. ALL DIMENSIONS ARE IN INCHES AND ARE SHOWN FOR REFERENCE ONLY.

| 0 | 09/23/09 | FIRST ISSUE | GJS | | | | |
|-----------|----------|-------------|-----|------|------|--|--|
| REV | DATE | DESCRIPTION | BY | APPD | REVD | | |
| REVISIONS | | | | | | | |

CUSTOMER PROMINENT FLUID CONTROLS INC.
(STANDARD COUPON RACKS)

2 COUPON RACK 1" PVC OPTION 1 DOLE

VALVE GENERAL ARRANGEMENT

PURCHASE ORDER No

THIS DRAWING IS THE PROPERTY OF PROMINENT FLUID CONTROLS INC. AND SHALL NOT BE COPIED OR TRANSFERRED WITHOUT THE WRITTEN CONSENT OF PROMINENT FLUID CONTROLS INC.

PITTSBURGH, PA USA

ENGINEERS SEAL

JOB No



7746432



WWW.PROMINENT.US

REV

0

PAGE

1/1

| PROMINENT FLU | JID CONTROLS LTD. | PROMINENT FLUID CONTROLS INC. | | |
|-------------------|-------------------|--|-------------------|--|
| 490 SOUTHGATI | E DRIVE. | RIDC PARK WEST 136 INDUSTRY DRIVE, PITTSBURGH P.A., USA. 15275 | | |
| GUELPH, ONTAI | RIO, CANADA | | | |
| N1H 6J3 | | | | |
| TEL. 519 836 5692 | FAX. 519 836 5226 | TEL. 412 787 2484 | FAX. 412 787 0704 | |
| DESIGNED | GJS | APPROVED | | |
| DRAWN | GJS | SCALE | N.T.S. | |
| CHECKED | JMS | DATE | 09/23/09 | |
| | | | | |

MAXIMUM TESTING PRESSURE = 150 PSI

MAXIMUM OPERATING PRESSURE = 150 PSI

CHEMICAL SERVICE = WATER

DWG №

7746432-200