



1. ALL PIPING AND FITTINGS SHALL BE 1/2" AND 3/4" SCH. 80 PVC SOCKET WELD WITH VITON SEALS UNLESS OTHERWISE NOTED.
2. EMULSION POLYMER BLENDING SYSTEM WITH THREE ZONE PVC MIXING CHAMBER.
3. REQUIRED INCOMING POWER:

120VAC, 60HZ, 1 PHASE, 15 AMP CURRENT RATING AT 120 VAC
4. ALL DIMENSIONS ARE IN INCHES AND ARE SHOWN FOR REFERENCE ONLY.

MAXIMUM TESTING PRESSURE =	150 PSI
MAXIMUM OPERATING PRESSURE =	65 PSI
CHEMICAL SERVICE =	POLYMER

0	12/04/12	FIRST ISSUE				GJS		
REV	DATE	DESCRIPTION				BY	APPD	REVD
REVISIONS								
CUSTOMER		PROMINENT FLUID CONTROLS INC. (PROMIX C SYSTEM)						
JOB No		7747054			PURCHASE ORDER No		N/A	
TITLE		PROMIX C_60-0.24TA SYSTEM SKID GENERAL ARRANGEMENT						
THIS DRAWING IS THE PROPERTY OF PROMINENT FLUID CONTROLS INC. AND SHALL NOT BE COPIED OR TRANSFERRED WITHOUT THE WRITTEN CONSENT OF PROMINENT FLUID CONTROLS INC.								
ENGINEERS SEAL		<div><div><div><div>pfc</div><div>ProMinent</div></div><div><div>ProMinent®</div><div>THE PROMINENT GROUP OF COMPANIES</div></div></div></div>						
		PITTSBURGH, PA USA				WWW.PROMINENT.US		
		PROMINENT FLUID CONTROLS LTD. 490 SOUTHGATE DRIVE. GUELPH, ONTARIO, CANADA N1H 6J3 TEL. 519 836 5692 FAX. 519 836 5226				PROMINENT FLUID CONTROLS INC. RIDC PARK WEST 136 INDUSTRY DRIVE, PITTSBURGH P.A., USA. 15275 TEL. 412 787 2484 FAX. 412 787 0704		
		DESIGNED GJS				APPROVED KH		
		DRAWN GJS				SCALE N.T.S.		
		CHECKED KH				DATE 12/04/12		
		DWG No		7747054-200				REV 0