


- NOTES:
- ALL PIPING AND FITTINGS SHALL BE 1/2" SCH. 80 PVC SOCKET WELD WITH EPDM SEALS UNLESS OTHERWISE REQUIRED BY COMPONENTS.
 - ALL DIMENSIONS ARE IN INCHES AND ARE SHOWN FOR REFERENCE ONLY.

| | | | | | |
|--|----------|---|--|-------------------|----------|
| | | | | | |
| A | 05/14/09 | REVISED PER BASIC SKID | | GJS | |
| 0 | 02/01/08 | FIRST ISSUE | | GJS | |
| REV | DATE | DESCRIPTION | | BY | APPD REV |
| REVISIONS | | | | | |
| CUSTOMER PROMINENT FLUID CONTROLS INC. (PRE-ENGINEERED SYSTEM) | | | | | |
| JOB No | | 7749043 | | PURCHASE ORDER No | |
| TITLE SS1-B_FLOOR_050_PVC\EPDM_DEGASS_FM GENERAL ARRANGEMENT | | | | | |
| THIS DRAWING IS THE PROPERTY OF PROMINENT FLUID CONTROLS INC. AND SHALL NOT BE COPIED OR TRANSFERRED WITHOUT THE WRITTEN CONSENT OF PROMINENT FLUID CONTROLS INC. | | | | | |
| ENGINEERS SEAL | | <div><div></div><div>ProMinent[®] THE PROMINENT GROUP OF COMPANIES</div></div> | | | |
| | | <div><div>PITTSBURGH, PA USA</div><div>WWW.PROMINENT.US</div><div><div>PROMINENT FLUID CONTROLS LTD. 490 SOUTHGATE DRIVE. GUELPH, ONTARIO, CANADA N1H 6J3 TEL. 519 836 5692 FAX. 519 836 5226</div><div><div>PROMINENT FLUID CONTROLS INC. RIDC PARK WEST 136 INDUSTRY DRIVE, PITTSBURGH P.A., USA. 15275 TEL. 412 787 2484 FAX. 412 787 0704</div></div></div></div> | | | |
| | | <div><div>DESIGNED GJS</div><div>APPROVED</div><div>DRAWN GJS</div><div>SCALE N.T.S.</div><div>CHECKED DTH</div><div>DATE 02/01/08</div></div> | | | |
| DWG No | | | | REV | PAGE |
| 7749043-200 | | | | A | 1/1 |

| | |
|------------------------------|---------|
| MAXIMUM TESTING PRESSURE = | 150 PSI |
| MAXIMUM OPERATING PRESSURE = | 150 PSI |
| CHEMICAL SERVICE = | |