


NOTES:

1. ALL PIPING AND FITTINGS SHALL BE 1/2" SCH. 80 CPVC SOCKET WELD WITH VITON SEALS UNLESS OTHERWISE REQUIRED BY COMPONENTS.
2. ALL VALVES TO BE VENTED.
3. ALL DIMENSIONS ARE IN INCHES AND ARE SHOWN FOR REFERENCE ONLY.

A	05/14/09	REVISED PER BASIC SKID	GJS	
0	02/08/08	FIRST ISSUE	GJS	
REV	DATE	DESCRIPTION	BY	APPD/REV
REVISIONS				
CUSTOMER PROMINENT FLUID CONTROLS INC. (PRE-ENGINEERED SYSTEM)				
JOB No 7749103		PURCHASE ORDER No		
TITLE SS1-E_FLOOR_050_CPVC/VITON-V_FM GENERAL ARRANGEMENT				
THIS DRAWING IS THE PROPERTY OF PROMINENT FLUID CONTROLS INC. AND SHALL NOT BE COPIED OR TRANSFERRED WITHOUT THE WRITTEN CONSENT OF PROMINENT FLUID CONTROLS INC.				
ENGINEERS SEAL		<div><div></div><div><div>ProMinent®</div><div>THE PROMINENT GROUP OF COMPANIES</div></div></div>		
		<div><div><div>PITTSBURGH, PA USA</div><div>PROMINENT FLUID CONTROLS LTD. 490 SOUTHGATE DRIVE, GUELPH, ONTARIO, CANADA N1H 6J3 TEL: 519 836 5692 FAX: 519 836 6226</div></div><div><div>WWW.PROMINENT.US</div><div>PROMINENT FLUID CONTROLS INC. RDC PARK WEST 136 INDUSTRY DRIVE, PITTSBURGH P.A., USA. 15275 TEL: 412 787 2484 FAX: 412 787 6704</div></div></div>		
DESIGNED GJS		APPROVED		
DRAWN GJS		SCALE N.T.S.		
CHECKED DTH		DATE 02/08/08		
DWG No 7749103-200			REV A	PAGE 1/1

MAXIMUM TESTING PRESSURE = 150 PSI
 MAXIMUM OPERATING PRESSURE = 102-150 PSI
 CHEMICAL SERVICE =