








- NOTES:
- ALL PIPING AND FITTINGS SHALL BE 1/2" SCH. 80 PVC SOCKET WELD WITH VITON SEALS UNLESS OTHERWISE REQUIRED BY COMPONENTS.
 - ALL DIMENSIONS ARE IN INCHES AND ARE SHOWN FOR REFERENCE ONLY.



MAXIMUM TESTING PRESSURE =	150 PSI
MAXIMUM OPERATING PRESSURE =	29-150 PSI
CHEMICAL SERVICE =	

B	05/06/09	REVISED PER BASIC SKID		GJS		
A	07/16/08	ADDED PIPE CLIPS		ALS		
0	01/14/08	FIRST ISSUE		GJS		
REV	DATE	DESCRIPTION		BY	APPD	REVD
REVISIONS						
CUSTOMER PROMINENT FLUID CONTROLS INC. (PRE-ENGINEERED SYSTEM)						
JOB No		7749144		PURCHASE ORDER No		
TITLE SS2-C_FLOOR_050_PVC/VITON GENERAL ARRANGEMENT						
THIS DRAWING IS THE PROPERTY OF PROMINENT FLUID CONTROLS INC. AND SHALL NOT BE COPIED OR TRANSFERRED WITHOUT THE WRITTEN CONSENT OF PROMINENT FLUID CONTROLS INC.						
ENGINEERS SEAL		pfc ProMinent ProMinent® THE PROMINENT GROUP OF COMPANIES PITTSBURGH, PA USA WWW.PROMINENT.US PROMINENT FLUID CONTROLS LTD. 490 SOUTHGATE DRIVE. GUELPH, ONTARIO, CANADA N1H 6J3 TEL. 519 836 5692 FAX. 519 836 5226 PROMINENT FLUID CONTROLS INC. RIDC PARK WEST 136 INDUSTRY DRIVE, PITTSBURGH P.A., USA. 15275 TEL. 412 787 2484 FAX. 412 787 0704 DESIGNED GJS APPROVED DRAWN GJS SCALE N.T.S. CHECKED DTH DATE 01/14/08				
DWG No		7749144-200		REV B	PAGE 1/1	