



- NOTES:
- ALL PIPING AND FITTINGS SHALL BE 1/2" SCH. 80 PVC SOCKET WELD WITH VITON SEALS UNLESS OTHERWISE REQUIRED BY COMPONENTS.
  - ALL DIMENSIONS ARE IN INCHES AND ARE SHOWN FOR REFERENCE ONLY.



|                              |             |
|------------------------------|-------------|
| MAXIMUM TESTING PRESSURE =   | 150 PSI     |
| MAXIMUM OPERATING PRESSURE = | 102-150 PSI |
| CHEMICAL SERVICE =           |             |

|  |          |   |  |                   |             |
|--|----------|---|--|-------------------|-------------|
|  |          |   |  |                   |             |
| A  | 05/06/09 | REVISED PER BASIC SKID  |  | GJS               |             |
| 0  | 01/14/08 | FIRST ISSUE   |  | GJS               |             |
| REV  | DATE     | DESCRIPTION   |  | BY                | APPD/REV    |
| REVISIONS  |          |   |  |                   |             |
| CUSTOMER <b>PROMINENT FLUID CONTROLS INC.<br/>(PRE-ENGINEERED SYSTEM)</b>  |          |   |  |                   |             |
| JOB No   |          | 7749151   |  | PURCHASE ORDER No |             |
| TITLE <b>SS2-E_FLOOR_050_PVC/VITON<br/>GENERAL ARRANGEMENT</b>   |          |   |  |                   |             |
| THIS DRAWING IS THE PROPERTY OF PROMINENT FLUID CONTROLS INC. AND SHALL NOT BE COPIED OR<br>TRANSFERRED WITHOUT THE WRITTEN CONSENT OF PROMINENT FLUID CONTROLS INC. |          |   |  |                   |             |
| ENGINEERS SEAL   |          | <div><div><div><div>ptc</div><div>ProMinent</div></div><div><div>ProMinent®</div><div>THE PROMINENT GROUP OF COMPANIES</div></div></div></div>  |  |                   |             |
|  |          |   |  |                   |             |
|  |          | <div><div>PITTSBURGH, PA USA</div><div>WWW.PROMINENT.US</div><div><div><div>PROMINENT FLUID CONTROLS LTD.<br/>490 SOUTHGATE DRIVE.<br/>GUELPH, ONTARIO, CANADA<br/>N1H 6J3<br/>TEL. 519 836 5692      FAX. 519 836 5226</div><div><div>PROMINENT FLUID CONTROLS INC.<br/>RIDC PARK WEST<br/>136 INDUSTRY DRIVE,<br/>PITTSBURGH P.A., USA. 15275<br/>TEL. 412 787 2484      FAX. 412 787 0704</div></div></div><div><div><div>DESIGNED</div><div>DRAWN</div><div>CHECKED</div></div><div><div>GJS</div><div>GJS</div><div>DTH</div></div><div><div>APPROVED</div><div>SCALE</div><div>DATE</div></div><div><div></div><div></div><div>01/14/08</div></div></div></div></div> |  |                   |             |
| DWG No   |          | 7749151-200   |  | REV<br>A          | PAGE<br>1/1 |