

- 1. ALL PIPING AND FITTINGS SHALL BE 1/2"(20MM) SR232 PVDF FUSION WELD WITH VITON SEALS UNLESS OTHERWISE REQUIRED BY
- 2. ALL DIMENSIONS ARE IN INCHES AND ARE SHOWN FOR REFERENCE

0	01/21/08	FIRST ISSUE	GJS						
REV	DATE	DESCRIPTION	BY	APPD	REVD				
REVISIONS									
CUSTOMER DROMINENT FLUID CONTROL CINIC									

CUSTOMER PROMINENT FLUID CONTROLS INC. (PRE-ENGINEERED SYSTEM)

JOB No 7749247

PURCHASE ORDER No

SS2-C\_FLOOR\_050\_PVDF\VITON\_PD\_FM GENERAL ARRANGEMENT

THIS DRAWING IS THE PROPERTY OF PROMINENT FLUID CONTROLS INC. AND SHALL NOT BE COPIED OR TRANSFERRED WITHOUT THE WRITTEN CONSENT OF PROMINENT FLUID CONTROLS INC.

ENGINEERS SEAL






PITT	PITTSBURGH, PA USA		WWW.PROMINENT.US			
PROMINENT FLU	PROMINENT FLUID CONTROLS LTD.		PROMINENT FLUID CONTROLS INC.			
490 SOUTHGATE	490 SOUTHGATE DRIVE. GUELPH, ONTARIO, CANADA N1H 6J3		RIDC PARK WEST 136 INDUSTRY DRIVE,			
GUELPH, ONTAF						
N1H 6J3			PITTSBURGH P.A., USA. 15275			
TEL. 519 836 5692	FAX. 519 836 5226	TEL. 4	112 787 2484 F	AX. 412 787 0704		
DESIGNED	GJS	APP	APPROVED  SCALE N.T.S.  DATE 01/21/08			
DRAWN	GJS	SCA				
CHECKED	DTH	DAT				
			REV	PAGE		
49247-200	١		0	1/1		
+3241-200	,		U	1/1		

SIDE VIEW

MAXIMUM TESTING PRESSURE = MAXIMUM OPERATING PRESSURE = 29-232 PSI

150 PSI DWG No 7749247-200 CHEMICAL SERVICE =



FRONT VIEW