

## DULCOMETER Aegis-II® Cooling Tower and Boiler Controller


Use your Tablet or Smartphone. I'm WiFi ready!



Please carefully read these operating instructions before use! - Do not discard this manual! The operator shall be responsible for any damage caused by installation or operating errors! Technical changes reserved.

**Sidebars:** Are used to explain typical uses for feed and control functions.

## Contents

|       |  |    |
|-------|--|----|
| 1     | Day-to-Day Browsing .....  | 4  |
| 1.1   | The WiFi Connection.....   | 4  |
| 1.1.1 | Using a PC or Tablet: .....  | 4  |
| 1.1.2 | Using a Smartphone .....   | 5  |
| 1.1.3 | Opening the Browser page using WiFi.....   | 6  |
| 1.2   | The LAN Connection.....  | 7  |
| 1.3   | The Home Screen.....   | 10 |
| 1.4   | Home Page Services .....   | 11 |
| 1.4.1 | Log-In.....  | 11 |
| 1.4.2 | Home Page Detail .....   | 11 |
| 1.4.3 | Home Page System Icons .....   | 13 |
| 1.4.4 | Create a Report .....  | 14 |
| 1.4.5 | Manage the report database  ..... | 17 |
| 1.5   | View & Adjust Setpoints .....  | 18 |
| 1.6   | Priming-Testing Pumps & Solenoids.....   | 20 |
| 2     | Blowdown Controls: Towers, Boilers, Closed Loops .....   | 21 |
| 2.1   | Conductivity Controlled Blowdown .....   | 21 |
| 2.2   | Boiler Blowdown .....  | 23 |
| 2.3   | Metered Blowdown.....  | 24 |
| 2.4   | Percentage Time Blowdown .....   | 25 |
| 2.5   | Variable Cycles.....   | 26 |
| 2.6   | Blowdown Limit Alarms .....  | 27 |
| 2.7   | Blowdown Interlocks-Flowswitches .....   | 28 |
| 2.8   | Blocking-Delaying a Blowdown.....  | 29 |
| 2.9   | Blowdown Diagnostics .....   | 30 |
| 3     | Chemical Feed Controls: Inhibitor, Acid, Oxidant, Amine.....   | 31 |
| 3.1   | Water Meter Inhibitor Feed .....   | 31 |
| 3.2   | Sensor Controlled Feeds .....  | 33 |
| 3.3   | Proportional Feed.....   | 35 |
| 3.3.1 | Bleed Based Feed .....   | 35 |
| 3.3   | Proportional Feed .....  | 36 |
| 3.3.2 | Time Modulation .....  | 36 |
| 3.3.3 | Timed Cycling .....  | 37 |
| 3.3.4 | PID Controls (Relays 6 through 9 only) .....   | 38 |
| 3.4   | Base Feed.....   | 39 |
| 3.5   | Control During Events .....  | 40 |
| 3.6   | Limiting Feed & Alarms .....   | 41 |
| 3.7   | No Feed on No Flow .....   | 43 |
| 3.8   | Blocking-Delaying a Feed .....   | 44 |
| 3.9   | Feed Diagnostics.....  | 45 |
| 4     | Biocide Events & Other Controls: Feeding by Time & Date .....  | 47 |
| 4.1   | Setting & Viewing Events .....   | 47 |
| 4.2   | Prebleed – Lockout .....   | 49 |
| 4.3   | Alarm Relay.....   | 50 |
| 4.4   | Sensor Wash .....  | 51 |
| 5     | Sensors: Conductivity, pH, ORP, Corrosion, 4-20mA.....   | 52 |
| 5.1   | Sensor Calibration: .....  | 52 |
| 5.1.1 | Single Point – Grab Sample.....  | 52 |
| 5.1.2 | DPD: Oxidant Sensors.....  | 53 |
| 5.1.3 | Boiler Conductivity .....  | 54 |

## AEGIS II Browser

|        |  |    |
|--------|--|----|
| 5.1.4  | pH Dual Buffer Calibration 1 of 2 .....                      | 55 |
| 5.1.5  | 4-20mA Input Loop Calibration 1 of 3 .....                   | 57 |
| 5.1.6  | Inventory .....  | 60 |
| 5.1.7  | LSI & Manual Inputs 1 of 2 .....                             | 61 |
| 5.1.8  | CTFS Flowswitch Calibration .....                            | 63 |
| 5.1.9  | Corrosion Rate Calibration .....                             | 63 |
| 5.2    | Sensor Alarms 1 of 2 .....                                   | 64 |
| 5.3    | Sensor Setup 1 of 2 .....                                    | 66 |
| 5.4    | Sensor Compensation .....                                    | 68 |
| 5.5    | Sensor Diagnostics 1 of 3 .....                              | 69 |
| 5.6    | Using Sensor Attributes for Phantoms .....                   | 72 |
| 5.7    | Inventory: Using feed meters & pumped volumes .....          | 73 |
| 6      | Measuring Volume: Water Meters, Inventory, Verify Feed ..... | 74 |
| 6.1    | Configuring a New Meter .....                                | 74 |
| 6.2    | Copying, Flow Rate Alarms & Rate-to-Volume .....             | 75 |
| 6.3    | Meter Diagnostics .....                                      | 76 |
| 6.4    | Meter Alarms .....   | 77 |
| 7      | Flowswitches, Interlocks & Contact Sets .....                | 78 |
| 7.1    | Switching Meters & Contact Sets .....                        | 78 |
| 7.2    | Contact Set Alarms .....                                     | 79 |
| 7.3    | Logically Inverting Contact Sets .....                       | 80 |
| 7.4    | Fail-to-Feed .....   | 80 |
| 7.5    | Mirroring a Control ON/OFF .....                             | 81 |
| 8      | Frequency Controlled Pumps .....                             | 82 |
| 8.1    | Selecting a Pump, Adjust mL/stoke & SPM .....                | 82 |
| 9      | 4-20mA Outputs .....   | 83 |
| 9.1    | Configure: Manual-Auto Switch .....                          | 83 |
| 9.2    | Adding Special Control to 4-20mA Outputs .....               | 84 |
| 9.3    | Calibrate a 4-20mA Output .....                              | 85 |
| 9.4    | Diagnostic & Mirroring .....                                 | 86 |
| 10     | System Settings .....  | 87 |
| 10.1   | Home & Diagnostic pages .....                                | 87 |
| 10.2   | Activity Log: .....  | 88 |
| 10.2.1 | User ID, time stamp .....                                    | 88 |
| 10.3   | Communications: 1 of 2 .....                                 | 89 |
| 10.3.1 | LAN IP, Netmask, MAC, Gateway, Wifi IP .....                 | 89 |
| 10.3.2 | Com card setup .....   | 90 |
| 10.4   | E-Mail Setup – Test .....                                    | 91 |
| 10.5   | Time & Date: .....   | 93 |
| 10.5.1 | Sync to Device .....   | 93 |
| 10.6   | Enable I/O: .....  | 94 |
| 10.6.1 | Enable IO, Assign to System# .....                           | 94 |
| 10.7   | System Setup: .....  | 95 |
| 10.7.1 | Naming, Sunday=Day1 ,Metric Units, Restart Options .....     | 95 |
| 10.8   | Passwords: 1 of 2 .....                                      | 96 |
| 10.8.1 | View-Set Access Level - Admin .....                          | 96 |
| 10.8.2 | View-Set Access Level - Users 1 - 7 .....                    | 97 |
| 11     | Appendices: .....  | 98 |

# AEGIS II Browser

## 1 Day-to-Day Browsing

The purpose of this manual is to show the user how to connect to the Aegis II controller using an Ethernet connection, or wirelessly via WiFi from a PC, tablet or smart phone. Secondly, to give examples of how to program the outputs, calibrate sensors and/or view the process.

The Installation and Operation manual has detailed sensor information, keypad instruction and controller details and specification.

The following sections detail connecting your smart device or PC to the controller. WiFi has the advantage of not requiring a physical cable. LAN setup follows this chapter, then the Home screen is explained as it is common to either connection method.

### 1.1 The WiFi Connection

A **WiFi** connection eliminates cables and the need to change your IP address.

There are two steps needed to fully connect to the controller. **Step 1:** Connect your device to the wireless network that includes your controller. **Step 2:** Enter the IP address of the controller in a browser app. There could be multiple devices on this network.

Step 1 is provided in two parts, [1.1.1 Using a PC or Tablet](#) and [1.1.2 Using a Smartphone](#)

#### 1.1.1 Using a PC or Tablet:

Click on the **WiFi** icon on your desktop.




Click on the AegisII\_123 choice and press the Connect button.

The number **123** in this example will be different on each controller. These 3 digits are taken from the last 3 digits of the controller serial number. This allows you to differentiate between controllers if more than one is within **WiFi** range.

Further differentiate your controller WiFi name. Edit the name in the System pages. See [10.3.1 LAN IP, Netmask, MAC, Gateway, Wifi IP](#)

You are now on the Aegis II **WiFi** network.

Continue with section [1.1.3 Opening the Browser page](#)



#### Sidebar:

Once you are connected to a controller, you can edit the SSID (WiFi name) to make identification easier than trying to remember the three digits.

See section [10.3 Communications](#) to make this change.

## AEGIS II Browser

### 1.1.2 Using a Smartphone

Navigate to your Smartphone setting page. Select the WiFi page. Select the AegisII\_123 choice.

NOTE: The number **123** will be different on each controller. These 3 digits will be the same as the last 3 digits of the controller serial number. This allows you to differentiate between controllers if more than one is within WiFi range.



#### Sidebar:

Once you are connected to a controller, you can edit the SSID (WiFi name) to make identification easier than trying to remember the three digits.  
See section **10.3 Communications** to make this change.



**Here are examples using Android and iPhone;**

#### 1.1.2.1 Setting up WiFi using an Android phone

From your home page, press the settings button then choose Wi-Fi.



There may be more than one controller nearby. Choose your controller by comparing the serial numbers last 3 digits with the options on the phone. Select your controller. The status should change for that choice. See example picture below; AegisII\_060 is 'Connected, no Internet'.



Continue with section **1.1.3 Opening the Browser page using WiFi**


## AEGIS II Browser

### 1.1.2.2 Setting up WiFi using an iPhone


To connect your iPhone to an AegisII controller, make a **WiFi** connection; Select the Settings button from your desktop.




Select the **WiFi** button.



Choose your controller.



Note the connection status.




If you have more than one Aegis choice, the number on the screen represents the last 3 digits of the AegisII controller serial number.


### 1.1.3 Opening the Browser page using WiFi

Once a WiFi connection is established, continue here with step 2. To connect to the controller and see the screen, open a browser and enter the controller's **WiFi** IP address. (Not the LAN IP). The default address is 192.168.1.1. If you do not see the connection status followed by the main page, it could be due to the WiFi address having been changed on the controller. Find the controller **WiFi** IP address using the controller keypad.

- 1) Press the Menu key
- 2) Press the up arrow (scroll up) until you see System. Press OK
- 3) You should be at the Communications menu. Press OK.
- 4) You will see the LAN IP address. Press the down arrow twice to see the WiFi IP Address. This is the address you need to use in the browser URL box. No need to add the WWW or Http. Just enter as shown here. 192.168.1.1 and press your return key.



Connection status



Once connected, you can see values and status of many I/O point but you will not be able to edit or make programming changes without logging in. This is the **HOME** screen.

## AEGIS II Browser

See section [1.3 The Home Screen](#)

### 1.2 The LAN Connection

The most common connection is via a Local Area Network (LAN) connection. This requires an Ethernet cable and you will need to set up your Ethernet port to match the address of the controller.

The Ethernet cable no longer needs to be a 'crossover' type unless you are running a Windows version earlier than VISTA. WIN7 onward will determine which wires need to be transmit and receive and adjust to match the signals on the cable.

Attach the cable to the LAN port on your PC and to the LAN port inside the controller. (Lower left-hand corner). A green light should be seen on both ports. The amber light will blink with each packet that passes by in either direction.

#### 1.2.1.1 Determine the LAN IP address of the controller

The default LAN IP address is 10.10.6.106. If you have not changed it and if the controller has not been placed on the customers network, try this address. If it does not work, find the LAN address;

Press the menu key on the controller  
Use the up arrow to System and press Enter  
Press Enter for Communication  
The LAN IP address is shown

Once you have determined the IP address of the controller, you need to set a static IP address on your PC that is compatible with the controller address.


#### 1.2.1.2 Setup the Local Area Connection on your PC

Depending on which version of Windows you are using, these instructions will vary. The idea is to set a compatible static IP address on your PC for the Ethernet port you will use to physically connect to the controller.

Use the following instructions for VISTA, WIN7, WIN8 and WIN10.

Hold down the Windows key  while you press the letter 'r'.



Enter 'ncpa.cpl' in the **Open** box.  
Press **OK**.





## AEGIS II Browser

Double click on **Local Area Connection** and select **Properties**



- (1) Highlight Internet Protocol **Version 4** (TCP/IPv4)
- (2) Select Properties



## AEGIS II Browser


Select the 'Use the following IP address': circle (1)

Enter the first three numbers of the controller's IP address (2)

Example: 010.010.006.\_\_\_\_

Then enter a number between 000 and 255 that is different from the controller address

In this example, since the controller IP is 010.010.006.106, we used 010.010.006.101 (3)



Press the Tab key and enter the Subnet mask of 255.255.255.0

Select OK here and on the Local Area Connection window

### Sidebar:

If you change the port number from the default address of 80, the WiFi port address will be changed automatically as well.

When the port number is 80, it is implied, therefore, you do not include it in the addressing.

However, if it is other than 80, you need to include it when you try to connect to the controller.

For example: if you change the address to 100, the default LAN IP address will now be entered as such:

10.10.6.106:100


The WiFi default address is now:

192.168.1.1:100

# AEGIS II Browser

## 1.3 The Home Screen

The home screen is divided into several sections or groups. Select icons for information or other menus. The I/O sections with dark blue background each have an assigned letter or number in a circle. Select the circle for menu choices for that point. **E** **1** These menus are explored in detail throughout this manual.



View from a Smartphone.

Scroll in any direction to access all I/O as shown in the above PC/Tablet screen.



# AEGIS II Browser

## 1.4 Home Page Services

From the home page, you can see all the enabled inputs and outputs (I/O). Log-in to gain access to three levels of programming privileges. Operator has the least benefit, while Admin has full access.

### 1.4.1 Log-In

Once you are connected, log in by selecting a username and enter a password.

#### Username with Default Passwords:

Operator1 = 1 Operator2 = 2 Operator3 = 3 Operator4 = 4.

Configure5 = 5 Configure6 = 6 Configure7 = 7 Administrator = AAAA

**Login Page:** Operators can view all controller pages. No access to most System pages.  
Configure users can edit the program. No access to most System pages.

#### Modify Passwords:

If the controller is accessible on the site LAN, you should modify all 8 passwords.


Two users cannot share the same password because only the password is used to identify keypad users. The controller displays **Password Fail** on a duplicate password.

See section **10.8 Passwords** to learn how to change passwords.

### 1.4.2 Home Page Detail


Now that you are logged in, you can edit the controller as well as monitor the action. The following pages break the Home page into sections to enhance identification.

#### 1.4.2.1 Analog Input Display



AEGIS II Browser

Analog Input Display continued



1.4.2.2 Digital I/O Display



Max of 8 Digital inputs: Can be any combination of dry contact switches or digital watermeter signals from contact head or paddle wheel models.

See section 9 for 4-20mA Output configuration

Max of 5 Digital Output Relays to power pumps, solenoids and MOV valves

Digital output configuration covered in sections 2, 3 and 4.

Max of 4 Pulse frequency or On/Off relays

AEGIS II Browser

Contacts

S

Flow switch

ON :5.8min

Meters

Setpoint

XYZ Inhibitor

(OFF)

Turbine meter

00000000 G

O

Bleed meter

00000000 G

P

mA Outputs

I

pH to DCS

12.59 mA

CAL

53.71%

J

4-20mAOutput

4.00 mA

CAL

0.00%

Power Relays

1

XYZ Inhibitor

Setpoint

2

Blowdown

ON: 5.5min

3

Acid

Timed Cycling

4

ABC Biocide

No Event

5

Alarm Output

Alarmed

Digital Outputs

6

Bleach Pump

Setpoint

8

EFG Biocide

No Event

9

P9 unused


No Event

1.4.3 Home Page System Icons

The home page has a variety of services unrelated to the program. These services are accessed via the icons in the upper left corner of the page.





## AEGIS II Browser


The User Manuals icon  gives you access to the two Aegis manuals; Operating and Browser (this manual). The Operating manual explains the keypad usage, wiring and specifications. The Browser manual shows you how to connect to and program an Aegis II controller.

The System Settings icon  has the following menus:   
These menus are explained in sections **10 System Settings**.


| System:        |
|----------------|
| Home           |
| Home           |
| Diagnostic     |
| Activity Log   |
| Communications |
| E-mail Setup   |
| Time & Date    |
| Enable I/O     |
| System Setup   |
| Passwords      |

The change display icon  allows users with dual systems to select how I/O points are displayed. See section **10.7 System Setup**

The report icon  opens the report page. See section **1.4.4 Create a Report**

Finally, the alarm icon  displays current alarms. Clear them from this menu page.

### 1.4.4 Create a Report

To create a report, select the report icon  from the main screen.



Follow the three steps as shown.

**1. Choose a date range**

Today

Today

Last 3 days

Last 7 days

Last 14 days

Custom...

1. Choose a date range.

**1. Choose a date range**

Custom...

Start Date

June

1

2018

End Date

June

14

2019

Date range must be less than 31 days

The 'Custom' selection lets you create a graph of any range that exist in the database. There is a 31-day limit.



# AEGIS II Browser

1. Choose a date range

Today

2. Choose up to four I/O's

Sensors (1)

CT1

☐ Fluorescent - [G]

CT2

CT1 | CT2

☒ Tower Cond. - [A]

☐ PAA - [C]

☐ 4-20mA Input - [D]

☐ ORP Sensor - [J]

☐ Unassigned - [K]

☐ Rate - [L]

☐ Makeup Cond. - [M]

☐ Calculate ppm - [N]

Meters (1)

CT1

CT2

CT1 | CT2

☒ Water meter - [O]

☐ Turbine meter - [P]

☐ Water meter - [Q]

☐ Water meter - [R]

☐ GMX Total - [W]

Contacts (1)

CT1

CT2

CT1 | CT2

☒ Flowswitch - [S]

☐ Contact set - [T]

☐ Contact set - [U]

Outputs

CT1

CT2

CT1 | CT2

☐ Chlorine Pump - [1]

☐ Bleed - [2]

☐ Acid Pump - [3]

☐ PAA Run Time Al - [4]

☐ Alarm out - [5]

☐ Alarm out - [6]

☐ No Flow Alarm - [7]

☐ PAA Feed - [8]

☐ P9 unused - [9]

mA Outputs

CT1

CT2

☐ pH Output - [F]

CT1 | CT2

☐ Conductivity Out - [E]

2 Select the I/O you wish to graph. Four points maximum. Checked boxes turn orange. After four boxes are checked, the remaining choices grey out and cannot be selected without unchecking one of the four.

2. Choose up to four I/O's

Sensors (1)

CT1

☐ Fluorescent - [G]

CT2

CT1 | CT2

☒ Tower Cond. - [A]

☐ PAA - [C]

☐ 4-20mA Input - [D]

☐ ORP Sensor - [J]

☐ Unassigned - [K]

☐ Rate - [L]

☐ Makeup Cond. - [M]

☐ Calculate ppm - [N]

Meters (1)

CT1

CT2

CT1 | CT2

☒ Water meter - [O]

☐ Turbine meter - [P]

☐ Water meter - [Q]

☐ Water meter - [R]

☐ GMX Total - [W]

Contacts (1)

CT1

CT2

CT1 | CT2

☒ Flowswitch - [S]

☐ Contact set - [T]

☐ Contact set - [U]

Outputs (1)

CT1

CT2

CT1 | CT2

☐ Chlorine Pump - [1]

☒ Bleed - [2]

☐ Acid Pump - [3]

☐ PAA Run Time Al - [4]

☐ Alarm out - [5]

☐ Alarm out - [6]

☐ No Flow Alarm - [7]

☐ PAA Feed - [8]

☐ P9 unused - [9]

mA Outputs

CT1

CT2

☐ pH Output - [F]

CT1 | CT2

☐ Conductivity Out - [E]

3 Press the Download button.

3. Download and view

Download data and create report

# AEGIS II Browser

Once the graph is open, the icons have the following properties.



- ? Access the controller manuals
- 🏠 Exit from the report menu back to the Live view
- 📋 Show/hide the report menu
- 🗄️ Manage the report database
- 📄 Show/hide the controller header
- 🔔 Show/acknowledge current alarms

Note the trend zoom tools.


Click on this icon to export as a picture



# AEGIS II Browser


## 1.4.5 Manage the report database

When you create a graph by selecting I/O points, the browser downloads the data for the chosen points. This data is stored on your device (PC, smart phone, etc). Different browsers allow different amounts of memory to this file. The graph page keeps track of previous selections and expresses the total size of all downloaded data in a bar graph.



This picture depicts three previous graph configurations that have data in the graphing database. Click on one to create a graph, or remove them by selecting the X.

If you wish to keep the configuration but want to reduce the data, open the Manage Report Database window and make your selection. Press Delete.



# AEGIS II Browser

## 1.5 View & Adjust Setpoints

Select the **1 to 9** icon on the home page. This example adjusts the Relay 1 setpoint

Select **Adjust Setpoint** from the pull-down

Bleed controls turn ON at the higher setpoint & then OFF @ the lower setpoint as the conductivity is lowered by the low conductivity make-up water

Edit one or both setpoints & **Submit**

In this example, we **Submit** a new setpoint, logging the activity

Frequency or 'Pulse' controls feed chemical proportionally between setpoints. In this example the pump would feed @ 50% of rated when the pH = 7.45

100% pulses the pump @ its maximum frequency

Setpoint change

| Status | Setpoint change |
|--------|-----------------|
| 100%:  | 7.50 pH         |
| 0%:    | 7.40 pH         |

### Sidebar:

Relays controlled by sensors power Pumps and Solenoids ON and OFF.

(Relays are outputs **1 to 5** & outputs **6 to 9** set to 'ON/OFF')

Frequency controlled Pumps feed chemicals at varying rates.

(Frequency controlled pumps are outputs **6 to 9** set to 'Pulse')

Tower Bleed solenoids use Setpoints 5uS to 20uS apart so that short bleeds are followed by short feeds. The resulting control has minimum variation in Inhibitor ppm and operates as close as possible to the target cycles of concentration.

ON-OFF Acid pumps use setpoints 0.05 pH apart so that the re-circulation delay between feeding acid and measuring its pH does not cause wide pH swings.

**WARNING:** Reversing setpoint order is blocked for ON/OFF controls but allowed for proportional Pulse controls. Reversing setpoints in this example would convert an Acid feed to a Caustic feed.

## AEGIS II Browser

### View & Adjust Setpoints continued

Setpoint values vary with the configuration of each control and the type of control output; ON/OFF or variable frequency (pulse).

The image displays four screenshots of the AEGIS II Browser interface, each showing a different control's 'Adjust Setpoint' screen. Callouts provide additional context for each screen:

- 5:Blr5 Treatment:** Shows 'Measure' set to 100 G and 'Feed' set to 10 seconds. A callout states: "Feeding on volume allows you to set the feedwater concentration. This example uses an ON/OFF pump".
- 8:Sulfite Feed:** Shows 'Measure' set to 100 G and 'Feed' set to 10 ppm. A callout states: "Using a frequency controlled pump simplifies setting a feed concentration". Another callout points to the 'Feed' field: "Refer to 3.1 for feed setup".
- 8:Sulfite Feed (Pulse):** Shows 'Percent Time' set to 18.5 %. A callout states: "In this example, a Pulse control has been configured to ON/OFF, ON 18.5% of every 5 minutes".
- 9:Dispersant:** Shows 'Base Feed' set to 12.5 mL/minute. A callout states: "In this example, a Pulse control feeds continuously. Typically the feed would be interlocked with a flowswitch or boiler run contact set from the site DCS."

#### Sidebar:

Controls may be configured to prevent one chemical feeding while another feeds (See 'Blocking') into a common injection header.

Inhibitor feeds may be delayed while the bleed solenoid is ON to prevent pumping inhibitor down the drain (See Section 3.)

Pumps or blowdown valve controls may be turned OFF when the tower or boiler is offline (See Interlocks)

Pay attention to the number **1** to **9** that precedes the pump, valve or solenoid name. It's the physical location on the controller circuit board of the wiring that connects to the pump, valve or solenoid.

You may modify the name of the pump, valve or solenoid but you'll need to know which output is controlling so you can check that enclosure cover indicating light is ON when the pump, valve or solenoid is ON. (Relays 1-5 on the LHS & Pulse 6-9 on the RHS)

## AEGIS II Browser

### 1.6 Priming-Testing Pumps & Solenoids

Select the 1 to 9 icon on the home page. This example primes the Relay 3

Select **Prime-Test** from the pull-down

Time remaining until end of Prime-Test

3:Inhibitor Feed

Prime-Test

START ☒ Yes ☐ No

Prime, Force ON 8.5 minutes

Refresh Submit

Edit the Prime-Test Time & **Submit**

3:Inhibitor Feed

Prime-Test

Remaining 00:08:24

End of Prime-Test ☐ Yes ☒ No

Refresh Submit

Select **End of Prime-Test = Yes** to end sooner & **Submit**

3:Inhibitor Feed

Prime-Test

Status Interlocked

START ☒ Yes ☐ No

Prime, Force ON

Refresh Submit

If the control is 'Blocked', 'Stopped', 'Interlocked' or 'Alarmed-OFF', Priming does not occur.

7:Acid Pump

Prime-Test

START ☒ Yes ☐ No

Prime, Force ON 200.0 mL

Refresh Submit

Pulse controls prime on volume, not time

7:Acid Pump

Prime-Test

Remaining 195 mL

End of Prime-Test ☐ Yes ☒ No

Refresh Submit

**Refresh** to update time or volume remaining

#### Sidebar:

Priming may also be used to slug feed on system start-up in addition to testing pumps, valves or solenoids. Feed limit alarms may stop priming.



## 2 Blowdown Controls: Towers, Boilers, Closed Loops

### 2.1 Conductivity Controlled Blowdown

Select the 1 to 9 icon on the home page. This example sets up the Relay 1 as a Bleed Control

Select **Setup** from the pull-down

Each control has 3 possible **Control Types**: **Blowdown** controls conductivity in Towers & Boilers

There are 3 possible **Blowdown** modes. Select **Sensor Control** to use a Conductivity sensor to control the blowdown valve or bleed solenoid.

Select the sensor used to control the blowdown. This pull-down selects from installed conductivity & toroidal sensors, 4-20mA inputs & 'Phantoms' of 'Unassigned' type

Select **Configure** from the pull-down

Rename the control for your site. Max. 16 characters.

Inherits the units from the controlling sensor. Rename if required-preferred. Max 3 characters.

Sets the number of digits after the decimal point used for setpoints. Inherits from controlling sensor. Unless a condensate control, fractional uS of little utility

Towers & Boiler lower the conductivity when the bleed-blowdown opens & make-up-feedwater dilutes the circulating water. **Note 1.**

'None' for typical tower controls. See 2.2 for Boiler blowdown & 2.5 for Varying Cycles.

This relay cannot be disabled because it is in use to Prebleed Relay 2

| 1: Tower276 Bleed  |                   |
|--|-------------------|
| Setup  |                   |
| Control Type   | Blowdown          |
| Set Blowdown Mode  | Sensor Control    |
| Control by:  | A: Tower Conduct. |
| <input type="button" value="Refresh"/> <input type="button" value="Submit"/> |                   |

| 1: Tower276 Bleed  |                     |
|--|---------------------|
| Configure  |                     |
| Descriptor   | Tower276 Bleed      |
| Display Units(UOM)   | uS                  |
| Decimal digits   | 0                   |
| Used by I/O  | 2: Biofeed on 2     |
| Control Action   | ON decreases sensor |
| Special Control  | None                |
| <input type="button" value="Refresh"/> <input type="button" value="Submit"/> |                     |

#### Sidebar:

**Note 1:** Closed loop conductivity controls usually use **Control Action ON increases sensor**. Select **Control by: More than one** to bleed on the ratio of tower to make-up conductivities. See next page.

## AEGIS II Browser

### Conductivity Controlled Blowdown continued

If you have a conductivity sensor installed in the tower make-up line, you can control on the ration of the tower conductivity to the make-up conductivity.

**CAUTION:** If your tower has a long holding time or large circulating volume or you are running the chemistry close to the scaling limit, look closely at control effects. Auto-Increasing cycles of concentration (make-up conductivity falls) when the bulk of the tower water has not changed, may scale heat exchangers.

1: Tower276 Bleed

Setup

|                   |                |
|-------------------|----------------|
| Status            | Reconfigured   |
| Control Type      | Blowdown       |
| Set Blowdown Mode | Sensor Control |
| Control by:       | A/E            |

Refresh

Submit

To remove ratio controls,  
Submit a blank Control By:  
setting the control back to 'None'

Selecting Control by: More than one on the Configure page allows you enter a ratio control equation. In this example we are controlling in the rationof the sensor connect to input 'A' (Tower Conductivity) to the sensor conncted to input 'E' (Make-up Conductivity)

Ratio of conductivities sets the default units to cycles & the default setpoints to 3.00 Adjust Setpoint for your application.

Set the cycles deadband (On-Off) narrow, for minimum change in chemistry as the bleed valve opens, the float adds make-up & the cycles fall.

1: Tower276 Bleed

Adjust Setpoint

|      |          |
|------|----------|
| On:  | 3.00 cyc |
| Off: | 2.98 cyc |

Refresh

Submit

#### Sidebar:

If this is a new tower to you, take the time to watch a bleed cycle.

The bleed opens but the conductivity continues to increase until the float opens.

(If you have a meter on the make-up you'll see it increment volume @ a higher rate)

The conductivity then starts to fall & may continue to fall after the bleed has turned OFF, depending on the float dead band.

You can't control inside of the float dead band but you can see the parts of the blowdown control: sensor, solenoid, meter, float ... all working.

# AEGIS II Browser

## 2.2 Boiler Blowdown

Select the 1 to 9 icon on the home page.  
This example sets up the Relay 4 as a Boiler Blowdown

Select **Configure** from the pull-down

The timing of Captured Sample blowdown controls varies with boiler usage, piping size & length from boiler to sensor, pressure, needle valve setting & feedwater quality. Modify timing & **Submit**.

Blowdown lowers boiler conductivity

Lower pressure commercial boilers use Captured Sample on the surface blowdown line for TDS control. **Note 1**.

Blowdown valve opens long enough to clear the surface blowdown line to the sensor, delivering a representative hot, un-flashed sample & goes to **Measure**. **Note 2**.

Valve closed. Sample cools a fixed & repeatable amount. Conductivity is measured @ the end of the measure interval. **Note 3**.

If conductivity above the setpoint, valve opens & blows down for **Blowdown** period, then goes to **Measure**

If conductivity below the setpoint, waits for ReSample time & goes to Sample. **Note 4**.

Optional thermal switch @ sensor alarms if blowdown valve fails to open, piping valved OFF...

| 4:Boiler_4_CS  |   |
|--|---|
| Configure  |   |
| Descriptor   | Boiler_4_CS   |
| Display Units(UOM)   | uS  |
| Decimal digits   | 0   |
| Disable  | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Control Action   | ON decreases sensor   |
| Special Control  | Captured Sample   |
| Sample   | 30 seconds  |
| Measure  | 60 seconds  |
| Blowdown   | 120 seconds   |
| ReSample   | 60 minutes  |
| Fail-to-Sample   | U:Thermal Switch  |
| <input type="button" value="Refresh"/> <input type="button" value="Submit"/> |   |

### Sidebar:

**Note 1.** Higher pressure, utility-power generation boilers use a continuous blowdown & a sample cooler to measure conductivity.

**Note 2:** Sensor installed upstream of the blowdown valve-solenoid & throttling needle valve. Needle valve downstream of blowdown valve. Lower reliability, steam rated solenoids limited to very low pressure boilers.

**Note 3:** If you modify **Measure** time or needle valve setting. Recalibrate because you've changed the temperature at the measure point.

**Note 4:** Boilers which cycle up slowly can extend Resample time to minimize **Sample** energy, water & chemical losses. Process boilers may need to **Sample** more frequently.

## AEGIS II Browser

### 2.3 Metered Blowdown

Select the 1 to 9 icon on the home page. This example sets up the Relay 1 as Meter controlled Bleed.

Select **Setup** from the pull-down

Select **Set Blowdown Mode = Water meter** & select the controlling meter & **Submit**.

1: Tower276 Bleed

Setup

Status: Reconfigured

Control Type: Blowdown

Set Blowdown Mode: Water meter

Control by: O: Tower Make-up

Refresh Submit

Adjust Setpoint

Measure: 500 G

Feed: 75 seconds

It would be unusual to control cycles using a single watermeter; however usable as a temporary fix on loss of a conductivity sensor.

1: Tower276 Bleed

Setup

Control Type: Blowdown

Set Blowdown Mode: Water meter

Control by: O:P

Refresh Submit

At sites where fouling or high silica prevents using contact conductivity sensors, two meter controls are **useable if make-up water chemistry constant**

Select **Control By = More than one** & edit to get a Makeup:Bleed sequential control. In the example 'O' is the make-up meter & 'P' the bleed.

Measure 300 Gallons or Make-up & then Bleeds 100 Gallons. Cycles of concentration = 3.

1: Tower276 Bleed

Adjust Setpoint

Measure: 300 G

Bleed: 100 G

Refresh Submit

#### Sidebar:

Toroidal (non-contact) conductivity sensors are also used in towers where fouling blocks contact type, conventional sensors.

### 2.4 Percentage Time Blowdown

Select the **1 to 9** icon on the home page. This example sets up the Relay 1 as a time controlled Bleed.

Select **Setup** from the pull-down

It would be unusual to control cycles using a **Percent Time** control; typically used as a temporary fix on loss of a conductivity sensor.

Select **Set Blowdown Mode = Percent Time** & Submit.

Setpoint is the % of every five minutes. In this example 25% = 75 seconds in every 5 minutes

**1: Tower276 Bleed**

**Status** Reconfigured

**Control Type** Blowdown

**Set Blowdown Mode** Percent Time

Refresh Submit

**1: Tower276 Bleed**

**Adjust Setpoint**

**Percent Time** 25.0 %

Refresh Submit

#### Sidebar:

Blowdown controls like other controls can be interlocked with flowswitch(es) or run contact sets & are subject to run time limits - alarms & blocking by other controls.

For example, if you use a **Percent Time** control to blowdown while you replace a sensor or meter, the bleed will turn OFF while the inhibitor feeds if you have configured the bleed to be 'Blocked by' the inhibitor pump.

However the bleed time owed in the current 5 minute cycle will be delivered when the inhibitor feed ends.

## 2.5 Variable Cycles

**1: Tower276 Bleed**

**Configure**

|                    |                     |
|--------------------|---------------------|
| Descriptor         | Tower276 Bleed      |
| Display Units(UOM) | cyc                 |
| Decimal digits     | 2                   |
| Used by I/O        | 2: Biofeed on 2     |
| Control Action     | ON decreases sensor |
| Special Control    | Varying Cycles      |
| uS Maximum         | 3000 uS             |
| High Cycles        | 2.500               |
| uS Hi Range        | 1000 uS             |
| Med. Cycles        | 4.250               |
| uS Med Range       | 650 uS              |
| Low Cycles         | 6.100               |
| uS Lo Range        | 350 uS              |

Refresh Submit

If your make-up changes seasonally or periodically and you have a 2<sup>nd</sup> conductivity sensor installed in the tower make-up line you can control using **Varying Cycles**.

No not use **Varying Cycles** if:

1. The holding time or turnover time of the tower is 'long' then the bulk of the tower water has not changed when the make-up conductivity changes & you may scale if hardness limited. 'Long' is site specific and a function of temperature, water chemistry and treatment program.
2. The make-up conductivity does not track the component that limits the maximum cycles. For example, hardness may increase with conductivity but silica may not & you may be silica limited.

**Varying Cycles** is not a **Special Control** option until **Control By:** is set to the ratio of the Tower-to-Makeup conductivities, **A/F** in this example

Set the maximum allowed tower water conductivity

When the Make-up conductivity ('F' in this example) is less than 1000uS, the tower bleed is controlled to 2.5 cycles of concentration

When the Make-up conductivity is less than 650 uS, the tower bleed is controlled to 4.25 cycles of concentration

When the Make-up conductivity is less than 350 uS, the tower bleed is controlled to 6.1 cycles of concentration

Set **Blowdown Mode** = **Sensor Control** and **Control by:** to **More than one**. Then edit to the ratio of the [Tower]/[Make-up]. In this example the tower conductivity is measured @ input 'A' & the make @ input 'F'  
**Mathematical expressions require capitol letters! (A/F)**

**1: Tower276 Bleed**

**Setup**

|                   |                |
|-------------------|----------------|
| Control Type      | Blowdown       |
| Set Blowdown Mode | Sensor Control |
| Control by:       | A/F            |

Refresh Submit



## 2.6 Blowdown Limit Alarms

Select the 1 to 9 icon on the home page. This example uses the **Alarms** page for a blowdown control on Relay 1

Select **Alarms** from the pull-down

Adjust for the number of minutes that would represent a failure to control cycles of concentration, 2 hours in this example

The number of minutes in any one bleed cycle

**No** = Alarm Logs & Displays but does not turn OFF the bleed

**Yes** = Turns ON the alarm relay when Relay 1 alarms

The default sets **OFF on Alarm** = **No**, some blowdown is usually better than none

If you are using another relay or DO with the **Special Control** = **Alarm Output**, then you can elect to have Relay1 alarm trip that relay or DO

Most recent alarm for Relay 1

Yes & Submit resets the alarm

| Status         | Adjusted Alarm  |
|----------------|---|
| Mins/Actuation | 120.0 minutes   |
| OFF on Alarm   | Yes <input type="radio"/> No <input checked="" type="radio"/> |
| Alarm Relay    | Yes <input type="radio"/> No <input checked="" type="radio"/> |
| Reset Alarm    | Yes <input type="radio"/> No <input checked="" type="radio"/> |
| Limit:ON timer | 14:51 2016-Jul-11   |

Refresh Submit

### Sidebar:

#### Obvious Alarm Causes:

Failed or blocked blowdown valve or solenoid, blowdown line inadvertently valved OFF after tower maintenance. If solenoid intermittent, check the static head required to operate.  
 Faulted or debris blocked blowdown meter for towers using sequential meter control.

#### Less Obvious Causes:

Undersized bleed as load increases &/or make-up chemistry changes.  
 Adding more gray water make-up @ higher than expected conductivity.  
 Failure to adjust bleed setpoints as seasonal changes in make-up chemistry occur.

#### Self-Inflicted Causes:

Recalibrating a low reading conductivity sensor rather than cleaning it or identifying the cause of the low reading. Sensor subsequently fails to track tower conductivity. This alarm may indicate higher levels of water & inhibitor usage.

#### Note:

No blowdown ON time may indicate a float stuck ON or partially ON

# AEGIS II Browser

## 2.7 Blowdown Interlocks-Flowswitches

Select the **1 to 9** icon on the home page. This example uses the **Interlocked** page for a boiler blowdown interlock on Relay 4

Select **Interlocked** from the pull-down

An **Interlock** stops a control from turning **ON** when the interlock is **OFF**.  
If the control is **ON** when the Interlock turns **OFF**, the control turns **OFF**.

All enabled contact set type inputs are shown on the **Interlocked** page. Select or deselect one or more **Interlock & Submit**

In this example, the contact set input @ T must be **ON** for The Boiler 1 blowdown control on Relay 4 to run

Cooling tower feed systems use a common flowswitch to interlock the bleed & all the chemical feeds. Boiler blowdowns typically use a separate interlock for each boiler.

A cooling tower flowswitch typically comes from a CTFS sensor but can be from any digital input device that represents flow

In this example pulse output **8** controls a sulfite pump typically feeding into the Deaerator sump.  
If either Boiler 1 (T) or Boiler 2 (U) is online, we want the sulfite pump to be feeding so we select both to **Interlock & 'OR'** them.

A flowswitch is part of a CTFS serial conductivity sensor. The temperature and flowswitch signals from this sensor must be assigned to phantom inputs. See section 5.6 Sensor Attributes for Phantoms

Selecting more than one Interlock requires you to select **'OR'ed** or **'AND'ed**  
**OR** = Any selected Interlock **ON** turns **ON** the control  
**AND** = All selected interlocks **ON** to turn **ON** the control

| Status            | Interlock edit |
|-------------------|----------------|
| S:Flowswitch      | unused         |
| T:Boiler 1 OnLine | Interlock      |
| U:Boiler 2 Online | Interlock      |
| W:Flowswitch_A    | unused         |
| X:Contact set     | unused         |
| Y:Contact set     | unused         |
| Contact set       | 'OR'ed         |

### Sidebar:

Contact sets that are ON are usually CLOSED, but you may invert the ON state to be ON when the contact set is OPEN; Section 7.3

## 2.8 Blocking-Delaying a Blowdown

Select the 1 to 9 icon on the home page. This example uses the **Blocked by** page for a Tower bleed block on inhibitor feed

Select **Blocked By** from the pull-down

**Blocking** stops a control from turning **ON** when the blocking control is **ON** .  
More than one block may be selected

In this example, the **Inhibitor Feed** pump controlled by Relay **3 Blocks** the bleed to prevent inhibitor from going direct to drain.

Select which controls you wish to Block the bleed & **Submit**

If feeding an oxidant into a common header with other reactive chemicals, you may elect to block the other chemicals from feeding when feeding oxidant

| Status            | Blocking edit     |
|-------------------|-------------------|
| 1: Tower276 Bleed | <b>Blocked by</b> |
| 2: Biofeed on 2   | unused            |
| 3: Inhibitor Feed | <b>Blocks</b>     |
| 4: Boiler_1_CS    | unused            |
| 5: Blr5 Treatment | unused            |
| 6: P6 unused      | unused            |
| 7: Acid Pump      | unused            |
| 8: Sulfite Feed   | unused            |
| 9: Dispersant     | unused            |

Refresh Submit

### Sidebar:

**Warning:** A poorly conceived block may prevent a control from running or working correctly. In this example, if the tower is bleed limited or the inhibitor pump undersized & therefore ON for an extended period, bleed control may fault.

You could elect to have the Bleed Control block the Inhibitor Pump & if you set the Bleed Setpoint inside of the float conductivity change, you'll have little effect on Inhibitor Levels.

**Bleed then Feed** Inhibitor feed controls block the Inhibitor Pump by feeding after the bleed ends.

Blocking inhibitor feed is seldom used on larger circulating volume towers where the feed point is usually remote in time & volume from the bleed point.

## 2.9 Blowdown Diagnostics

Select the 1 to 9 icon on the home page. This example uses the Diagnostic page for a Tower bleed block on Relay 1

Select **Diagnostic** from the pull-down

Controlling sensor or control equation. In this example, the ratio of tower conductivity connected to 'A' & make-up connected to 'F'

Status: ON/OFF, blocked, interlocked, alarmed...

Current value of the control sensor or control equation

ON time since midnight

ON time in the current bleed cycle. In this example the same as **ON today** time, may indicate a control problem

This blowdown control is running the **Varying Cycles** special control

Added special control information. In this example, that we are running in the lowest range of make-up conductivity.

Refresh

4:Boiler\_1\_CS

This example is a **Special Control = Captured Sample** boiler blowdown control by the sensor connected to input 'F'.

Captured Sample controls only update the value of the controlling sensor @ the end of the **Measure** period

Why is the conductivity value so low?  
Did the sampling valve-solenoid fail to open?  
Did it fail to close & are we flashing @ the sensor?  
Are we valved OFF upstream?  
Did we just start-up & is the boiler cycling up?  
Diagnostics provide the information, you supply the context

The blowdown has only been ON 30 seconds today, likely a single Sample- Measure sequence

Currently in the **ReSample** delay period. In 11.3mutes, we'll open the blowdown valve-solenoid, **Sample**, close the Valve for the **Measure** period & update the value of 'F' the controlling conductivity. Then we'll either **Blowdown** or start another **ReSample** period.

| 1:Tower276 Bleed      |                     |
|-----------------------|---------------------|
| Diagnostic            |                     |
| Status                | Operational, ON     |
| Blowdown by: A/F      | 17.95 cyc           |
| 48.4m ON today        | 48.4m ON, actuation |
| Varying Cycles        |                     |
| ON uS Lo Range 350 uS |                     |
| Refresh               |                     |

| 4:Boiler_1_CS        |                      |
|----------------------|----------------------|
| Diagnostic           |                      |
| Status               | Special Control, OFF |
| Blowdown by: F       | 100 uS               |
| ON Setpoint          | 3000 uS              |
| OFF Setpoint         | 2990 uS              |
| Control Action       | Lower TDS            |
| 0.5m ON today        | 0.0m ON, actuation   |
| Captured Sample      |                      |
| ReSample OFF 11.3min |                      |
| Refresh              |                      |

### 3 Chemical Feed Controls: Inhibitor, Acid, Oxidant, Amine...

#### 3.1 Water Meter Inhibitor Feed

Select the **1 to 9** icon on the home page. This example uses the **Setup** page for an Inhibitor feed controlled by Relay **3**

Select **Setup** from the pull-down

Feeding using a water meter on the make-up or bleed, is among the most ppm accurate, reliable & easiest to adjust methods for sites with relatively constant feedwater chemistry

Select **Control Type = Feed**, select **Set Feed Mode = Water meter** & select the **Control by:** water meter, then **Submit**

After **Setup**, go to **Adjust Setpoint** & set for your target chemical ppm, pump setting, meter location...

**Measure** does not have to be a multiple of the meter setting, the control does the math

**Feed** is the pump ON time. estimated based on pump size, stroke & frequency setting or adjusted based on a ppm test result

If using a pulse or frequency controlled pump, each stroke delivers a fixed amount (of Dispersant in this example) so the **Feed** setpoint is in ppm

See Section 8.0 for ml/stroke defaults & adjustments.

#### Sidebar:

If using a water meter on the bleed & a pulse-controlled pump, the nominal inhibitor ppm in the tower is the Feed setpoint x% active/100; 100% if feeding neat.  
See following page for make-up meter example.

## AEGIS II Browser

### Water Meter Inhibitor Feed continued

It's common to feed inhibitor on the sum of potable-city & gray water make-ups.

If inhibiting for corrosion control, then you may wish to feed more on gray water make-up; increase the grey water meter scaling accordingly.

(A 100G/contact gray meter set to 200G/contact will double the feed).

If inhibiting for scale, then you may wish to feed less inhibitor on gray make-up; decrease the gray water meter scaling proportionately.

(A 100G/contact gray meter set to 50G/contact will halve the feed).

Changing the meter setup will also affect the totalized watermeter reading!

**3:Inhibitor Feed**

**Setup**

Control Type: **Feed**

Set Feed Mode: **Water meter**

Control by: **More than one**

Refresh Submit

To feed on the sum of 2 to 4 water meters select  
**Control by: More than one & Submit**

**3:Inhibitor Feed**

**Setup**

Status: Reconfigured

Control Type: **Feed**

Set Feed Mode: **Water meter**

Control by: **O+R**

Refresh Submit

Edit **Control by**: to be the sum of the target meters & **Submit**  
In this example, we're using a potable make @ input 'O' & a gray water make-up @ input 'R'

Removing complex control equations:  
**Submit** a blank **Control by**:  
Sets **Control by**: to **None**

#### Sidebar:

**Simplified example:** Yes, this begs for an app & likely you have access to one; if not:  
An 8 GPD pump with the meter on the make-up & running 4 cycles of concentration feeding a 50% active product & requiring 20 ppm of inhibitor in the recirculating tower water:

100 gallons of make-up needs a 10 ppm ( $20\text{ppm} \times 100\% / 50\% / 4 \text{ cycles}$ ) feed.

An 8 GPD pump feeds  $(8 \text{ G} / (24\text{hr.} \times 3600 \text{ sec/hr.}) 92.6\text{E}^{-6} \text{ G/sec.}$

Every 100 Gallons of make-up we'll need to feed ( $100\text{G} \times 10 \text{ ppm}$ )  $1\text{E}^{-3}$  gallons which @  $92.6\text{E}^{-6} \text{ G/sec}$  feed rate will take ( $1\text{E}^{-3} / 92.6\text{E}^{-6}$ ) 10.8 seconds

There are error sources: How accurate is the % active?

Is 8GPD @ site temperature range & static head? How accurate is the cycle control?.....

This is a first guess; test ppm & adjust.

If this is a start-up, use pump Prime to get to an initial ppm.



## AEGIS II Browser

### 3.2 Sensor Controlled Feeds

Select the 1 to 9 icon on the home page. This example uses the **Setup** page for an Oxidant feed controlled by Relay 2

Setting up a sensor controlled feed has 3 steps: **Setup, Configure & Adjust Setpoint**

Select **Setup** from the pull-down

Select **Control Type = Feed**, **Set Feed Mode = Sensor** & then select the controlling sensor for **Control by:** from the pull-down & **Submit**

Edit for your site, up to 16 characters

Inherited from the controlling ORP sensor. Units may be edited, up to 3 characters

Default is the correct Control Action for an oxidant where feeding increases the controlling ORP value. **ON decreases sensor** would be used for a bisulfite, de-chlor control

Setpoints for an ORP control will vary with site water chemistry & target ppm. Biologicals drive the ORP down. When it's **300 mV** the pump turns ON & stays ON until the ORP is **325 mV**

The interface consists of three main sections: Setup, Configure, and Adjust Setpoint.

**Setup Page:** This page is used to configure the basic settings for the feed. It includes a pull-down menu for the feed name (e.g., "2:Oxidant\_Control"), a pull-down menu for the feed mode (e.g., "Feed"), a pull-down menu for the set feed mode (e.g., "Sensor Control"), and a pull-down menu for the controlling sensor (e.g., "D:ORP Sensor"). There are "Refresh" and "Submit" buttons.

**Configure Page:** This page is used to configure the specific details of the feed. It includes a pull-down menu for the feed name (e.g., "2:Oxidant\_Control"), a text input field for the descriptor (e.g., "Oxidant\_Control"), a text input field for the display units (UOM) (e.g., "mV"), a pull-down menu for the decimal digits (e.g., "1"), a "Disable" section with "Yes" and "No" buttons (e.g., "No" is selected), a pull-down menu for the control action (e.g., "ON increases sensor"), and a pull-down menu for the special control (e.g., "None"). There are "Refresh" and "Submit" buttons.

**Adjust Setpoint Page:** This page is used to adjust the setpoint for the feed. It includes a pull-down menu for the feed name (e.g., "2:Oxidant\_Control"), a table with columns for "Status" and "Setpoint change", and "Refresh" and "Submit" buttons.

| Status | Setpoint change |
|--------|-----------------|
| On:    | 300.0 mV        |
| Off:   | 325.0 mV        |

## AEGIS II Browser

### Sensor Controlled Feeds continued

**7:Acid Pump**

**Setup**

|               |                |
|---------------|----------------|
| Control Type  | Feed           |
| Mode          | Pulse Output   |
| Set Feed Mode | Sensor Control |
| Control by:   | C:pH Sensor    |

Outputs 6 to 9 may be **Mode** configured as either **Pulse Output** or **ON/OFF Output**. Use Pulse for frequency controlled pumps & ON/OFF for Run/Stop controlled pumps.

In this example, we've configured output 7 for a frequency controlled pump

If **Mode = Pulse Output**, the **Configure** page will show the installed **Pump Type** its nominal **mL/stroke** setting.  
Default **mL/stroke** assumes 100% stroke  
Refer to Section 8. for detail on pump selector & settings

**7:Acid Pump**

**Configure**

|                    |   |
|--------------------|---|
| Descriptor         | Acid Pump   |
| Display Units(UOM) | pH  |
| Decimal digits     | 2   |
| Disable            | <input type="button" value="Yes"/> <input checked="" type="button" value="No"/> |
| Special Control    | None  |
| Pump Type          | ProMinent 0704  |
| mL/stroke          | 0.240   |

**7:Acid Pump**

**Adjust Setpoint**

|        |                 |
|--------|-----------------|
| Status | Setpoint change |
| 100%:  | 7.50 pH         |
| 0%:    | 7.45 pH         |

Pump speed varies linearly between setpoints with maximum strokes/minute set by **Pump Type**

If **Mode = ON/OFF Output**, the **Adjust Setpoint** fields will be **On:** & **Off:**

#### Sidebar:

**WARNING:** Reversing setpoint order is blocked for ON/OFF controls but allowed for proportional Pulse controls. Reversing setpoints in this example would convert an Acid feed to a Caustic feed.

**NOTE:** Relays 6 through 9 set in pulse output mode can be used to drive 4-20mA outputs. This allows the 4-20mA output to use Special Control programs: PID, Time Modulation and Timed Cycling.

## AEGIS II Browser

### 3.3 Proportional Feed

#### 3.3.1 Bleed Based Feed

**Bleed & Feed** and **Bleed then Feed** are used to feed inhibitor proportional to the tower bleed ON time. Commonly used on smaller towers without a make-up or bleed meter installed.

**Bleed & Feed** is usually only used when the tower is 'bleed limited', with the bleed undersized and ON for more than 50% of the time.

#### Sidebar:

**Bleed then Feed** is used to feed cooling tower inhibitor when a make-up meter is not available and the bleed is ON typically for less than 50% of the time that the tower is on-line.

If the tower Bleeds for **X** Minutes, the Inhibitor is fed for a user set % of **X** minutes AFTER the bleed ends. It's a better way to feed inhibitor for small cooling towers than **Bleed & Feed** since less inhibitor is lost down the drain.

Inhibitor savings averaging more than 20% were measured on a mix of small towers in California simply by switching from **Bleed & Feed** to **Bleed then Feed**.

#### Reliability:

**Bleed then Feed & Bleed & Feed** controls are only as reliable as the tower bleed solenoid and conductivity sensor. So set bleed limit alarms to trap control faults.

## AEGIS II Browser

### 3.3 Proportional Feed

#### 3.3.2 Time Modulation

**Time Modulation** allows an ON/OFF pump to operate like a frequency or 4-20mA controlled pump. ON-OFF pumps are typically set to maximum stroke and rate when **Time Modulation** is selected.

Select the 1 to 9 icon on the home page.  
This example uses the **Configure** page for an Oxidant feed controlled by Relay 2

Select **Configure** from the pull-down

2:Oxidant\_Control

Configure

|                    |   |
|--------------------|---|
| Status             | Reconfigured  |
| Descriptor         | Oxidant_Control   |
| Display Units(UOM) | mV  |
| Decimal digits     | 1   |
| Disable            | <input type="button" value="Yes"/> <input checked="" type="button" value="No"/> |
| Control Action     | ON increases sensor   |
| Special Control    | Time Modulate   |
| Period             | 120 seconds   |

Refresh Submit

Setup a sensor based control as shown in **Section 3.2 Sensor Controlled Feeds** then change **Special Control** from **None**

The selection of **Control Action** alters the ON & OFF time calculation in each **Period**

Select **Special Control** = **Time Modulate**  
And set the Modulation **Period** in seconds & **Submit**

In this example the setpoints are 50mV apart & the **Period** = **120** seconds.  
If the current ORP = 320mV then the pump would be ON for 72 seconds  
 $(120 \times (350-320)/(350-300))$   
and OFF for 48 seconds  $(120 - 72)$

The pump would be ON for 120 seconds in every 120 seconds @ the **On:** ORP & OFF for 120 seconds in every 120 seconds @ the **Off:** ORP

2:Oxidant\_Control

Adjust Setpoint

|        |                 |
|--------|-----------------|
| Status | Setpoint change |
| On:    | 300.0 mV        |
| Off:   | 350.0 mV        |

Refresh Submit

#### Sidebar:

**Time Modulate Special Control** is only selectable on Relays 1-5 and 6-9 only when they are set to **Mode = ON/OFF Output**.

## AEGIS II Browser

### 3.3 Proportional Feed

#### 3.3.3 Timed Cycling

**Timed Cycling** allows time for the controlling sensor to measure the effect of chemical before feeding more chemical. **Timed Cycling** is used where a chemical is fed occasionally into a system with a large volume.

It may be several minutes before the chemical travels from the injection point through the piping and sump and then back to the controlling sensor location at the recirculating pump.

Based on the setpoint, the relay will be on for the ON time in each period and off for the remainder of the period. Once the setpoint is reached, the relay will not turn on again until the setpoint calls for chemical. It is either on for the ON Time each period, or off for the complete period.

Select the 1 to 9 icon on the home page.  
This example uses the **Configure** page for an Oxidant feed controlled by Relay 2

Select **Configure** from the pull-down

Setup a sensor based control as shown in **Section 3.2 Sensor Controlled Feeds** then change **Special Control** from **None**

In this example, if the oxidant value drops below the setpoint, relay #3 will turn on for 60 seconds and then remain off for (600-60) 540 seconds. This will repeat each Period until the ORP value rises above the setpoint. The controller only compares the value with the setpoint at the start of a cycle. Once a cycle starts, the relay will either be on for the On Time or not come on at all.

1. Select **Special Control** = **Timed Cycling**

2. Set **Period** = OFF + ON Time, maximum 1800 seconds, 30 minutes

3. Set **ON Time** = maximum feed time in any Period & Submit

| 2:Oxidant_Control  |   |
|--|---|
| Configure  |   |
| Status   | Reconfigured  |
| Descriptor   | Oxidant_Control   |
| Display Units(UOM)   | mV  |
| Decimal digits   | 1   |
| Disable  | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Control Action   | ON increases sensor   |
| Special Control  | Timed Cycling   |
| Period   | 600 seconds   |
| ON Time  | 60 seconds  |
| <input type="button" value="Refresh"/> <input type="button" value="Submit"/> |   |

#### Sidebar:

Often there is a long time delay between adding a chemical and measuring its effect at a sensor which causes setpoint overshoot and poor control.

## AEGIS II Browser

### 3.3 Proportional Feed

#### 3.3.4 PID Controls (Relays 6 through 9 only)

**Warning:** An incorrectly configured PID control can be unstable or unresponsive when loaded or not. Wide swings in the sensor value can be the result of a poor configuration. If long delays (>5 minutes) exist in your control loop, or you are not experienced in PID control with long delays, we advise that you use a different proportional **Special Control**. (See section 3.3.2 and 3.3.3)

Select the 6 to 9 icon on the home page. This example uses the **Configure** page for an Oxidant feed controlled by Relay 7 in pulse mode

Select **Configure** from the pull-down

Setup a sensor based control as shown in **Section 3.2 Sensor Controlled Feeds** then change **Special Control** from **None** to **PID**

**7:Chlor Pump pulse**

**Configure**

|                    |   |
|--------------------|---|
| Status             | Reconfigured  |
| Descriptor         | Chlor Pump pulse  |
| Display Units(UOM) | mV  |
| Decimal digits     | 0   |
| Disable            | <input type="button" value="Yes"/> <input checked="" type="button" value="No"/> |
| Control Action     | ON increases sensor   |
| Special Control    | PID Control   |
| mL/stroke          | 0.100   |
| Rated SPM          | 240   |
| Xp Proportnl       | 20.000 mV   |
| Integral Rate      | 30 seconds  |
| Diffrence Rate     | 15 seconds  |

**7:Chlor Pump pulse**

**Adjust Setpoint**

PID Control 740 mV

PID Control only requires a single **Setpoint**

This example uses a pulse, variable frequency control. Selecting **PID Control** on a relay control adds a **Relay Period** field. The relay ON time is modulated by the PID control

Select **Special Control = PID Control**

**Never change two or more parameters at the same time. This includes the pump output.**

Proportional (band) is the range of control. 20mV (in this example) from the setpoint, the output will be at 100% on and proportionally diminish until at the setpoint, the output will be off.

The Integral rate effects how strongly the output responds to the error based on the amount of time the process and setpoint are different. A larger value will have less effect. Zero is off. Rule of thumb; set equal to 1.5x or 2x lag time.

**Lag Time:** Difference from the moment the chemical is added until the probe sees a change.

The difference rate is based on the rate of change in the process. Set for 0 (zero is off) and if the output has an oscillation that cannot be stopped using P and I, start to increase D slowly. 99% of customers will not need this parameter. Do not exceed 0.2x lag time.

## AEGIS II Browser

### 3.4 Base Feed

**Base Feed** is usually interlocked with a tower flowswitch or the boiler run contact set & feeds chemical continuously while the flowswitch is ON or boiler on-line.

Select the **1 to 9** icon on the home page.  
This example uses the **Setup** page for a Dispersant feed controlled by pulse output 9

Select **Setup** from the pull-down

1. Select **Control Type = Feed**  
2. Select **Mode = Pulse Output**  
3. Select **Set Feed Mode = Base Feed** & **Submit**

Then **Adjust Setpoint & Submit**  
The pump type & ml/stroke are viewed - selected on the **Configure** page.

Relay 1-5 controlled base feeds are the same as Pulse 6-9 outputs configured **Mode = ON/OFF output** with **Set Feed Mode = Percent Time** & **Submit**

Then **Adjust Setpoint & Submit**  
For ON/OFF **Percent Time** controls, the Setpoint = ON time in every 5 minutes.  
In this example 25% = 75 seconds ON in every 300 seconds

9:Dispersant

Setup

Control Type: Feed

Mode: Pulse Output

Set Feed Mode: Base Feed

Refresh Submit

9:Dispersant

Adjust Setpoint

Base Feed: 10.0 mL/minute

Refresh Submit

9:Dispersant

Setup

Control Type: Feed

Mode: ON/OFF Output

Set Feed Mode: Percent Time

Refresh Submit

9:Dispersant

Adjust Setpoint

Percent Time: 25.0 %

Refresh Submit



3.5 Control During Events

3:Oxidant\_Feed

Setup

Control Type

Feed

Set Feed Mode

Sensor Control

Control by:

G:CBR Bromine

Refresh

Submit

Select the 1 to 9 icon on the home page. This example uses the **Setup** page for an Oxidant feed controlled by Relay 3

Select **Setup** from the pull-down

Events only exist on the pull down if **Control Type = Feed** **Set Feed Mode = Sensor Control** & the control is an oxidant, **Bromine** in this example

Feed **Events** are set as detailed in the following Section 4.0

Application flexibility:  
1. **Event Control = No** works like normal biofeed feed event, feeding @ the current pump setting for the event duration.  
2. Typically, the event setpoint would be higher than the non-event setpoints. But the control also works with event setpoints less than non-event setpoints

3:Oxidant\_Feed

Adjust Setpoint

On:

2.0 ppm

Off:

2.1 ppm

Refresh

Submit

Adjust **Setpoint** controls the Relay 3 Oxidant Feed using these setpoints until an **Event** occurs.

During an **Event**, if **Event Control = No**, the control is ON for the Event period with no setpoint controls

During an **Event**, if **Event Control = Yes** these setpoints control

3:Oxidant\_Feed

Events

Day 2

2 Events weekly

Event Cycle

Weekly

Select Activity

Edit an Event

Select for Edit & Delete

Day 2 @ 11:45 for 5 minutes

Values for Add & Edit

Start Day

2 1-7

Start Time

11:45 HH:MM

ON Time

5 minutes

Event frequency

Once  
Alternate Days  
Daily

Event Control

☒ Yes ☐ No

ON Setpoint

5.0 ppm

OFF Setpoint

5.5 ppm

Aegis\_II\_Browser.doc

40

### 3.6 Limiting Feed & Alarms

Feed Limits are used both to prevent sensor controlled overfeeds & to block the effect of errors in adjusting feed rates or setpoints.

Configure both the alarm & response to the type of chemical & how you are controlling the feed.

Select the 1 to 9 icon on the home page. This example uses the **Alarms** page for an Inhibitor feed controlled by relay output 3

Select **Alarms** from the pull-down

You're usually not concerned about extended feed periods with inhibitors, so **Mins/Actuation** typically set to never trip

At the expected usage for this size tower @ max. load, cumulative feed over 4 hours/day indicates either a control problem or setpoint error. When **Minutes/Day** is exceeded, feed stops.

Inhibitor feeds usually set **Midnight Reset = Yes**, which auto resets alarms @ midnight allowing another **240.0 minutes** of feed in the following day

If you are using another relay or DO with the **Special Control = Alarm Output**, then you can elect to have Relay 3 alarm trip that relay or DO

Select **Reset Alarm = Yes & Submit** to clear alarms (see Sidebar)

Most recent alarm & it's type, if any. This one's a year old so we're not frequently alarming

| 3:Inhibitor Feed   |   |
|--|---|
| Alarms   |   |
| Mins/Actuation   | 500.0 minutes   |
| Minutes/Day  | 240.0 minutes   |
| Midnight reset   | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Alarm Relay  | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| Reset Alarm  | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| Limit: Time/Day  | 12:16 2015-Feb-22   |
| <input type="button" value="Refresh"/> <input type="button" value="Submit"/> |   |

#### Sidebar:

Unlike Blowdown controls, Feed controls stop feeding when alarmed. If alarmed on **Mins/Actuation**, the alarm ends the **Actuation** period, so **Reset Alarm = Yes & Submit** re-starts the feed.

If alarmed on **Minutes/Day**, **Reset Alarm** does not restart the feed because we've still exceeded the **Minutes/Day** limit. If you need to continue to feed, increase the **Minutes/Day** limit.

In either case. The alarms are either set too tight, operating conditions may have changed or there is a control-pump-feed-sensor problem.

## AEGIS II Browser

### Limiting Feed & Alarms continued

Alarms on feeds for acid, caustic or oxidants that are not tripping because they are set too tight to the normal operating or seasonal variation, usually indicate a maintenance response is required.

Make-up water chemistry may have changed. Towers may have added a gray water make-up or boilers may have deaerator problems or contaminated condensate return.  
Sensors age, foul & drift. Meter wiring may be sharing conduit with power wiring...

Frequency controlled pumps 6-9 have alarms set by pumped volume

7:Acid Pump

Alarms

|                |   |
|----------------|---|
| vol.@ MAX spm  | 0.5 G   |
| Volume/Day     | 12.7 G  |
| Midnight reset | <input type="button" value="Yes"/> <input checked="" type="button" value="No"/> |
| Alarm Relay    | <input checked="" type="button" value="Yes"/> <input type="button" value="No"/> |
| Reset Alarm    | <input type="button" value="Yes"/> <input checked="" type="button" value="No"/> |

Refresh Submit

Depending on the controlling sensor & the type of control, a sensor fault may cause the pump to ramp to maximum. This is the type of fault trapped by the **vol.@MAX spm** alarm

**Volume/Day** alarms stop feed on the volume pumped from midnight.  
It would be prudent to use both alarms on an acid feed control

Base Feed, PID & proportional feed controls may never completely turn OFF so Actuation volume alarms are less effective with frequency controlled pumps.

Acid feeds usually set **Midnight Reset = No**.  
If you are alarming, find the cause & correct

#### Sidebar:

Feed controls stop feeding when alarmed.  
If alarmed on **vol.@MAXspm**, the alarm ends feed cycle, so **Reset Alarm = Yes & Submit** re-starts the feed.

If alarmed on **Volume/Day**, **Reset Alarm** does not restart the feed because we've still exceeded the **Volume/Day** limit. If you need to continue to feed, increase the **Volume/Day** limit.

# AEGIS II Browser

## 3.7 No Feed on No Flow

Select the 1 to 9 icon on the home page.  
This example uses the **Interlocked** page for a Boiler treatment feed controlled by relay output 5

Select **Interlocked** from the pull-down

In this example, when the contact set @ input '**U**' **Boiler 2 Online** is **ON** then the relay 5 feed control runs.

Select **Interlock** @ the target input & Submit

In this example relay output 3 controls an inhibitor pump.  
  
If both **Flowswitch (S)** and **Low\_Level (U)** are **ON**, we want the inhibitor to be feeding so we select both to **Interlock** & '**AND**' them.  
(Avoiding both a loss of prime & pumping dry.)

Selecting more than one Interlock requires you to select '**OR**'ed or '**AND**'ed  
**OR** = Any selected Interlock **ON** turns **ON** the control  
**AND** = All selected interlocks **ON** to turn **ON** the control

**5:Blr5 Treatment**

**Interlocked**

| Status             | Interlock edit |
|--------------------|----------------|
| S:Flowswitch       | unused         |
| T:Boiler 1 OnLine  | unused         |
| U:Boiler 2 Online  | Interlock      |
| W:Flowswitch_A     | unused         |
| X:Therm_Flowswitch | unused         |
| Y:Contact set      | unused         |

Refresh Submit

**3:Inhibitor Feed**

**Interlocked**

| Status             | Interlock edit |
|--------------------|----------------|
| S:Flowswitch       | Interlock      |
| T:Boiler 1 OnLine  | unused         |
| U:Low_Level        | Interlock      |
| W:Flowswitch_A     | unused         |
| X:Therm_Flowswitch | unused         |
| Y:Contact set      | unused         |
| Contact set        | 'AND'ed        |

Refresh Submit

## 3.8 Blocking-Delaying a Feed

Select the 1 to 9 icon on the home page.  
This example uses the **Blocked by** page for an Inhibitor feed controlled by relay output 3

Select **Blocked** from the pull-down

**Blocking** stops a feed control from turning **ON** when the blocking control is **ON** .  
More than one block may be selected

In this example, the **Oxidant\_Control** pump controlled by Relay 2 **Blocks** the **Inhibitor Feed** on Relay 3 to prevent degrading the inhibitor in the common feed header

Select which controls you wish to Block the **Inhibitor Feed & Submit**

If feeding inhibitor controlled by a make-up meter or Bleed\_then\_Feed.... & the **Oxidant\_Control** blocks, owed inhibitor feed occurs when the **Oxidant Control** turns OFF

| Status            | Blocking edit |
|-------------------|---------------|
| 1:Tower276 Bleed  | unused        |
| 2:Oxidant_Control | <b>Blocks</b> |
| 4:Boiler_1_CS     | unused        |
| 5:Blr5 Treatment  | unused        |
| 6:P6 unused       | unused        |
| 7:Acid Pump       | unused        |
| 8:Sulfite Feed    | unused        |
| 9:Dispersant      | unused        |

Refresh Submit

### Sidebar:

**Warning:** A poorly conceived block may prevent a control from running or working correctly.

In this example, if the **Oxidant\_Control** runs long because the chlorine demand is not met or the control setpoints are set too far apart, inhibitor levels in the recirculating water may fault.

Generally (dependent on tower size, injection point & siting), once you've met the initial chlorine demand, setting ORP setpoints 5-10mV apart should result in short oxidant feed periods.

If you have a large inhibitor pump &/or short inhibitor feeds, you could get the same result by blocking the **Oxidant\_Control** with the inhibitor pump.

3.9 Feed Diagnostics

Select the 1 to 9 icon on the home page. This example uses the **Diagnostic** page for an **Acid Pump** controlled by pulse output 7

Select either the I/O icon on the home page or **Diagnostic** from the pull-down

**Diagnostic** provides both configuration & state detail on one page

Control state

|                  |                 |
|------------------|-----------------|
| Status           | Operational, ON |
| Feed by: C       | 7.32 pH         |
| 100% ON Setpoint | 7.50 pH         |
| OFF Setpoint     | 7.25 pH         |
| Control Action   | Between Sets    |
| -----            |                 |
| Volume today     | 0.288G          |

Location of controlling sensor, 'C' & value of the control.

Current setpoints

Feed state

Refresh

5:Blr5 Treatment

Control state

Location of controlling sensor, 'O' & value of the control.

Current setpoints

Note that  $1400\text{G} / 100\text{G} \times 10\text{sec} = 2.33$  minutes. But pump ON for **240.4** minutes today, so feed mode must have been changed.

Volume feed state

In this example: We've measured volume but have not fed all the time required, so there is **Time Owed**

|                 |                    |
|-----------------|--------------------|
| Status          | Operational, ON    |
| Feed by: O      | 1400 G             |
| Measure volume  | 100 G              |
| and Turn ON for | 10 seconds         |
| Last fed        | 1400 G             |
| -----           |                    |
| 240.4m ON today | 0.3m ON, actuation |
| Time Owed       | 2.0 min            |

Refresh

Feed Diagnostics continued

3:Inhibitor Feed

Diagnostic

|                    |                         |
|--------------------|-------------------------|
| Status             | Special Control,ON      |
| 5.7m ON today      | 5.7m ON, actuation      |
| <hr/>              |                         |
| Bleed then Feed    | Bleed OFF Feed 7475 sec |
| <div>Refresh</div> |                         |

Control state: In this example, the **Bleed then Feed Special Control** is controlling Relay 3

The **Bleed** is now **OFF** & we owe **7475** seconds of pump run time. Is a 2 hour bleed cycle normal for this site or does it indicate a problem?

9:Dispersant

Diagnostic

|                    |                       |
|--------------------|-----------------------|
| Status             | Special Control,ON    |
| 130.7m ON today    | 0.7m ON, actuation    |
| <hr/>              |                       |
| Percent Time,25%   | Countdown: 33 seconds |
| <div>Refresh</div> |                       |

Control state: In this example, the **Percent Time Special Control** is controlling 9 configured as an ON/OFF output

We're in the ON state for another 33 seconds of the 5 minute cycle. 25% of 5 minutes = 75 seconds

3:Inhibitor Feed

Diagnostic

|                    |                    |
|--------------------|--------------------|
| Status             | Interlocked S,OFF  |
| Feed by: O         | 2100 G             |
| Measure volume     | 100 G              |
| and Turn ON for    | 10 seconds         |
| Last fed           | 2100 G             |
| <hr/>              |                    |
| 130.8m ON today    | 0.0m ON, actuation |
| <div>Refresh</div> |                    |

Control state: In this example, the Inhibitor feed on relay 3 is controlled by the meter @ input 'O' is **OFF** because the Flowswitch @ input 'S' is **OFF** (**S Interlocks 3**)

If 'O' measures volume while interlocked, the feed for the measured volume will occur when 'S' turns ON

2:Oxidant\_Control

Diagnostic

|                    |                    |
|--------------------|--------------------|
| Status             | Blocked by 3 ,OFF  |
| 2.5m ON today      | 0.0m ON, actuation |
| <div>Refresh</div> |                    |

Control state: In this example, the **Oxidant Control** by relay 2 is Blocked & OFF when Relay 3 turns ON



### 4 Biocide Events & Other Controls: Feeding by Time & Date

#### 4.1 Setting & Viewing Events

Select the 1 to 9 icon on the home page.  
This example uses **Biocide A**  
controlled by relay 5

Select **Setup** from the pull-down  
& after **Submit**, select **Events**

Control Type: **Events-Other**  
Refresh Submit

Select **Control Type = Events-Other**  
& **Submit**

Day# in the current 28 day cycle.  
Monday, **Day 2** in this example  
May be reset to the current Sunday,  
See Section 10.7

**Daily, Weekly & 28 Day** programs can be mixed  
in one controller.  
Oxidants typically fed weekly with two organic biocides more  
commonly fed on alternating weeks using a 28 day program  
Dispersants may be fed daily

5:Biocide A

Events

Day 2 0 Events weekly

Event Cycle: **Weekly**

Select Activity: **Add an Event**

Select Activity = **Add an Event**

Start Day: **2**

Start Time: **7:00 HH:MM**

ON Time: **20 minutes**

Event frequency: **Once**  
**Alternate Days**  
**Daily**

Reset Submit

A new biocide control will  
have **0 Events** set

Events repeat  
**Daily, Weekly** or every **28 Days**  
Select the required **Event Cycle**.

In this example, the first event  
occurs on Monday, day **2**  
starting @ **7:00 AM**  
& feeding for **20 minutes**

In this example, we're also adding feed events on  
Wednesday, Friday & Sunday by selecting  
**Alternate Days** & **Submit**

#### Sidebar:

Relay 1-5 and ON-OFF 6-9 controls have timed events = **ON Time**.  
Pulse-frequency controls 6-9 have volume feed events = **Volume**.

## AEGIS II Browser

### Setting & Viewing Events continued

5:Biocide A

Events

Day 2 4 Events weekly

Event Cycle Weekly

Select Activity Edit an Event

Select for Edit & Delete

Day 1 @ 07:00 for 20 minutes

Values for Add & Edit

Start Day 1 1-7

Start Time 7:00 HH:MM

ON Time 20 minutes

Event frequency Once  
Alternate Days  
Daily

Reset Submit

In the previous page's example, 4 feed events on Monday, Wednesday, Friday & Sunday were added on **Submit**

Select Activity to  
Edit an Event  
Delete an Event  
Delete All Events  
Or  
Add an Event (see previous page)

Pull down this selector to view all of the events for this control & to select an event for Editing or Deleting

If Select Activity = Edit an Event or Add an Event the values in these fields are set on **Submit**.

#### Sidebar:

Limit Alarms, Interlocking & Blocking also are used with Biocide Events. They are set identically to those for **Chemical Feed Controls**. Refer to Sections 3.5 to 3.7 for setup & state pages.

Biocide feeds are always interlocked with the tower flowswitch.

Timed & Volume events can also be used to wash sensors, flush sumps, block other controls for event times....

## AEGIS II Browser

### 4.2 Prebleed – Lockout

| 5:Biocide A  |   |
|--|---|
| Configure  |   |
| Status   | Reconfigured  |
| Descriptor   | Biocide A   |
| Disable  | <input type="button" value="Yes"/> <input checked="" type="button" value="No"/> |
| Special Control  | Prebleed Lockout  |
| Lockout  | 120 minutes   |
| Prebleed   | 30 minutes  |
| Prebleed Sensor  | A: Tower Conduct.   |
| Prebleed OFF   | 750 uS  |
| Blowdown Relay   | 1: Tower276 Bleed   |
| <input type="button" value="Refresh"/> <input type="button" value="Submit"/> |   |

Select **Configure** on the Biocide Event control to setup **Prebleed Lockout**

Select **Special Control** = **Prebleed Lockout** & **Submit**.  
Then set-adjust the following parameters

**Lockout** is the time that the **Blowdown Relay** is blocked. Includes the Event time. Set = 0 for no **Lockout**.

**Prebleed** is the time that the **Blowdown Relay** is forced ON to lower the recirculating water conductivity before the Event runs. Set = 0 for no **Prebleed**.

**Prebleed Sensor** is the selected conductivity sensor which is used to limit the **Prebleed** time to **Prebleed OFF**. It's optional, however its use prevents wasting treated recirculating water

**Blowdown Relay** is the location of the tower bleed for this biocide control.

#### Sidebar:

**Prebleed-Lockout** is used to prevent to tower from making up during & diluting the biocide concentration. Use is determined by biocide type & required concentration-residence time

**Prebleed** is typically used for cycles limited towers with **Lockout** more common on towers inhibited for corrosion control. Few sites need to use both.

**Prebleed** costs both water & its inhibitor, but there may be no choice if hardness cycles limited. **Lockout** has a lower cost but not applicable for many sites.

## AEGIS II Browser

### 4.3 Alarm Relay

Select the control# icon from the right side of the home page

Select **Setup** from the pulldown

Verify **Control Type** = **Events-Other**

Then select **Configure** from the pulldown

Set **Special Control** = **Alarm Output** & **Submit**

| 5:Alarm_Relay |              |
|---------------|--------------|
| Setup         |              |
| Control Type  | Events-Other |
| Refresh       | Submit       |

| 5:Alarm_Relay   |   |
|-----------------|---|
| Configure       |   |
| Descriptor      | Alarm_Relay   |
| Disable         | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Special Control | Alarm Output  |
| Refresh         | Submit  |

#### Sidebar:

If **Special Control** = **Alarm Output** is set for a pulse-frequency control ( 6 to 9), the control is converted to an ON/OFF control on **Submit**.

# AEGIS II Browser

## 4.4 Sensor Wash

**Sensor Wash** is useable for systems-sites where all of the sensors are installed in a common header.

**Sensor Wash** locks all of the sensor values prior to starting the wash event, blocking alarms & unexpected sensor values on the HMIs.  
If concerned about other controls running during a wash, block (Section 3.7) the controls.

Select the control# icon from the right side of the home page

5:Sensor\_Wash

Configure

|                 |   |
|-----------------|---|
| Status          | Reconfigured                              |
| Descriptor      | Sensor_Wash                               |
| Disable         | <div>Yes</div> <div>✓</div> <div>No</div> |
| Special Control | Sensor Wash                               |
| Wash END delay  | 300 seconds                               |

Refresh

Submit

Select **Configure** from the pulldown

Sensor\_wash is only available on controls  
**Control Type = Events-Other**

Select **Special Control = Sensor Wash & Submit**

Then edit **Wash END delay** & Submit

Wash END delay is the time after the washing event has ended that sensor vlaues remain locked to allow recovery from washing

Sensor Wash events are set like all other feed events on either time (Relay controls 1 to 5 & ON/OFF Pulse controls) or pumped volume (Pulse controls 6 -9).

5:Sensor\_Wash

Events

|                 |                                   |
|-----------------|-----------------------------------|
| Status          | No Events set                     |
| Day 1           | 0 Events daily                    |
| Event Cycle     | Daily                             |
| Select Activity | Add an Event                      |
| Start Time      | 7:00 HH:MM                        |
| ON Time         | 20 minutes                        |
| Event frequency | Once<br>Alternate Hours<br>Hourly |

Reset

Submit

## 5 Sensors: Conductivity, pH, ORP, Corrosion, 4-20mA...

### 5.1 Sensor Calibration:

#### 5.1.1 Single Point – Grab Sample

Select the A to N icon on the home page or the **CAL** icon below the A-N icons.  
This example calibrates conductivity sensor connected to input 'A'

A: Tower Conduct. ✕

Calibrate

If using the A to N icon, select Calibrate from the pulldown

Enter value

Factory Reset

Grab sample from the sensor header & enter measured conductivity & select Calibrate

Calibrating locks out the local keypad user so that both users are not calibrating @ the same time.  
Cancel to remove the lock & exit calibration

A: Tower Conduct. ✕

Calibrate

Status Calibrated

Enter value

Factory Reset

In this example we edited the current 1650 uS to measure 1700 uS

Exit by selecting Cancel @ the end of Calibration or you'll lock out keypad calibration for this sensor for 15 minutes.

A: Tower Conduct. ✕

Calibrate

Status Out of Range

Sensor 3000 uS

Calib. Override

Factory Reset

Single point, grab sample calibration is typically used for controlling sensors which need to be accurate at the single point used for control

Each sensor type has calibration limits which usually indicate a sensor or installation problem, but not always.  
If you get an error message you can ignore it by Calib. Override = Yes & Submit

Factory Reset = Yes & Submit restores the sensor to its default values.  
Useful for pH, ORP & Conductivity sensors.  
New sensor value may indicate fouling or end-of-life state or allow you to recover from a faulted calibration procedure

Cancel leaves the sensor value unchanged, Removes the lock out on keypad calibration & exits.

## AEGIS II Browser

### 5.1 Sensor Calibration:

#### 5.1.2 DPD: Oxidant Sensors

Select the **A** to **N** icon on the home page or the **CAL** icon below the A-N icons. This example calibrates chlorine sensor connected to 4-20mA input C

If using the **A** to **N** icon, select **Calibrate** from the pulldown

Grab sample from the sensor installation header & press **Start**

**Start** saves the current value of the sensor for use when you complete the DPD test.

This page locks out the keypad due from calibration the sensor @ '**C**'. **Cancel** to exit the page & unlock.

When you have the result of the DPD test, edit the displayed value & **Calibrate**

Use **Cancel** to exit the DPD calibration

**Refresh** shows the time since the value @ **Start** was captured

**Calibrate** shows 'Calibrated' on success. **Cancel** to exit

**Factory Reset = Yes & Submit** restores the 4-20mA-to-ppm conversion to its factory default

if you get a calibration error message you can ignore it by **Calib. Override = Yes & Submit** or re-calibrate by selecting **Start**

The interface consists of three main sections. The top section is a header bar with the sensor name 'C:CLE3 Chlorine' and a pulldown menu set to 'Calibrate'. Below this is a table with rows for 'DPD Sample' (containing '& START'), 'Factory Reset' (with 'Yes' and 'No' radio buttons, 'No' is selected), and buttons for 'Start', 'Cancel', and 'Submit'. The middle section shows the result of the DPD test: 'CLE3 Chlorine' with a value of '2.35 ppm 14sec'. Below this are buttons for 'Calibrate', 'Refresh', and 'Cancel'. The bottom section shows the 'Status' as 'Calibrated', the 'DPD Sample' as '& START', and the 'Factory Reset' as 'Yes' (with a red arrow pointing to the 'Yes' button). Buttons for 'Start', 'Cancel', and 'Submit' are also present.

#### Sidebar:

The DPD calibration applies to CLB, CTE & CLE3 Chlorine, CGE, CBR Bromine & PAA Peracetic sensors. All of these sensors connect to 4-20mA input driver cards. The G input does not have the necessary voltage to power a loop for the ProMinent amperometric sensors. ProMinent does not recommend ORP sensor calibration. If the sensor is not tracking, clean with a mild acid. The Offset may be adjusted +/- 40mV if necessary. Rather, consider changing the setpoint. There are many non-oxidants that affect ORP sensors falsely.



## AEGIS II Browser

### 5.1 Sensor Calibration:

#### 5.1.3 Boiler Conductivity

Select the **A to N** icon on the home page or the **CAL** icon below the A-N icons. This example calibrates the boiler conductivity sensor connected to input E

If using the **A to N** icon, select **Calibrate** from the pulldown

The blowdown control is using **Special Control = Captured Sample**. **Calibration** includes services to verify the sensor installation

Select **Start** once you have an un-flashed sample to initiate the **Sample – Measure** sequence

Select **Cancel** to exit **Calibration**. Removes the calibration lockout for the keypad user & the calibration state from the blowdown valve control

Use **Refresh** to see the conductivity increase during the Sample period. Low or varying conductivity indicates flashing. No change may indicate no-sample

If you elect to edit the displayed conductivity & **Calibrate** before the end of **Sample - Measure**, the previous value conductivity will be used to calibrate.

If you edit the displayed conductivity & **Calibrate** after the end of **Measure**, the current, updated value conductivity will be used to calibrate.

**Refresh** during the **Measure** interval should show a stable & falling conductivity, verifying that the valve-solenoid has closed & that the sample is cooling a fixed & repeatable amount

Successful **Calibration**. Select **Cancel** to exit & remove keypad calibration lock-out

If an error message results, you can set **Calib. Override = Yes** & Submit or **Start** to re-calibrate

## AEGIS II Browser

### 5.1. Sensor Calibration:

#### 5.1.4 pH Dual Buffer Calibration 1 of 2

Select the **A to N** icon on the home page or the **CAL** icon below the A-N icons.  
This example calibrates the pH sensor connected to input C

If using the **A to N** icon, select **Setup** from the pulldown to verify **2 Point**

pH sensor calibration defaults to single point.  
To do a 2 buffer pH calibration  
select **Calibrate = 2 Point** & **Submit**.  
Then select **Calibrate** from the pull down

**Caution: Sensor Removal**  
Always close the sensor piping  
upstream valve first.  
pH, ORP sensors & sensor with  
membranes may fail  
on the high transient pressure  
caused by quickly closing  
the downstream valve first.

Press **Start**.  
Remove the pH sensor & place in the 1<sup>st</sup> buffer.  
Calibration defaults to 7 & 10 buffers.  
If you are not using a 7 buffer,  
edit the buffer value before **Start**.

**Start** locks the pH value for control and  
alarms during the 2 buffer clibrate sequence

The selected 1<sup>st</sup> buffer in this  
example is the default **7.00**

Select **Cancel** to exit **Calibration**.  
Removes the calibration lockout for the keypad user  
& unlocks the frozen value of pH

**Refresh** until the pH is stable  
& close to the buffer value.  
Then press **Next**.

Select **Cancel** to exit **Calibration**.

| Descriptor         | pH Sensor |
|--------------------|-----------|
| Display Units(UOM) | pH        |
| Decimal digits     | 2         |
| Calibrate          | 2 Point   |
| Used by I/O        | L,        |

| 1st pH buffer | 7.00 pH |
|---------------|---------|
| Factory Reset | Yes No  |

| 7.0 Buffer    | 7.04 pH 31sec |
|---------------|---------------|
| Factory Reset | Yes No        |

AEGIS II Browser

5.1 Sensor Calibration:  
pH Dual Buffer Calibration 2 of 2

C:pH Sensor

Calibrate

|               |          |
|---------------|----------|
| 7.0 Buffer    | 7.05 pH  |
| 2nd pH buffer | 10.00 pH |

NextCancel

Results from 1<sup>st</sup> buffer

If you are not using a 10 buffer, edit the buffer value before Next.

Select **Cancel** to exit Calibration.

C:pH Sensor

Calibrate

|               |   |
|---------------|---|
| 7.0 Buffer    | 7.05 pH   |
| 10.0 Buffer   | 9.61 pH 25sec   |
| Factory Reset | Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> |

CalibrateRefreshCancel

Refresh until the pH is stable & close to the 2<sup>nd</sup> buffer value. Then press **Calibrate**.

C:pH Sensor

Calibrate

|               |   |
|---------------|---|
| Status        | Calibrated  |
| 1st pH buffer | 7.00 pH   |
| Factory Reset | Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> |

StartCancelSubmit

Successful calibration. Press **Cancel** to exit Calibration.

C:pH Sensor

Calibrate

|                 |  |
|-----------------|--|
| Status          | Out of Rangel  |
| 7.0 Buffer      | 7.05 pH  |
| Sensor          | 10.00 pH   |
| Calib. Override | Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>                          |
| Factory Reset   | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> |

CancelRe-CalibrateSubmit

On error message, select **Calib. Override = Yes & Submit**  
Or  
**Re-calibrate** to do over  
Or  
**Cancel** to exit leaving the current pH value unchanged

Note: Two buffer pH calibration seldom results in better pH control than single point, grab sample calibration, but may be required by site practice

## AEGIS II Browser

### 5.1 Sensor Calibration:

#### 5.1.5 4-20mA Input Loop Calibration 1 of 3

4-20mA inputs may be single or two point calibrated if they do not require a DPD test.

Both options calibrate the sensor represented by the 4-20mA input & not the underlying 4-20mA current loop.

For example: If calibrating a 4-20mA Temperature sensor, you are correcting the sensor to read the current measured Temperature test.

Select the **A to N** icon on the home page or the **CAL** icon below the A-N icons. This example calibrates the 4-20mA sensor connected to input G

Once a sensor has been selected for control by a relay, the Setup menu changes. 'Sensor Type' will not be seen. In its place is a Used by note depicting the relay being controlled.

See section 3.2 Sensor Controlled Feeds. Choose a different sensor to release this sensor setup page. **Remember to return the sensor selection when done.**

If using the **A to N** icon, select **Setup** from the pulldown & check **Calibrate = 1 Point**

1:Acid Pump

Control Type: Feed

Set Feed Mode: Sensor Control

Control by: E:pH Sensor

Minimum ON time

Used by I/O 2,

G:4-20mA Input

Setup

Descriptor: 4-20mA Input

Display Units(UOM): C

Decimal digits: 2

Calibrate: 1 Point

Disable: Yes ☐ No ☒

Sensor Type: Other

20mA Value: 100.00 C

4mA Value: 0.00 C

Reset Submit

In this example we're going to single point Calibrate a Sensor Type = Other

G:4-20mA Input

Calibrate

Enter value: 50.01 C

Factory Reset: Yes ☐ No ☒

Calibrate Cancel

Edit the sensor value & **Calibrate** Status = **Calibrated** & displays new value

Status: Calibrated

Enter value: 48.50 C

Factory Reset: Yes ☐ No ☒

Calibrate Cancel

Cancel To exit & to unlock keypad calibrate access

## AEGIS II Browser

### 5.1 Sensor Calibration: 4-20mA Input Loop Calibration 2 of 3

On this page we are 2 point calibrating a 4-20mA Temperature sensor.  
Verify the **Setup** page **Calibrate = 2 Point** & select **Calibrate** from the pull down.

**G:4-20mA Input**

**Calibrate**

|                  |   |
|------------------|---|
| Enter 1st value  | 25 C  |
| Calibrate 4-20mA | Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> |
| Factory Reset    | Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> |

Start Cancel Submit

In this example we're going to 2 point Calibrate a Sensor Type = Other which requires (in this example) that you either put the temperature sensor into 2 solutions of differing temperatures OR use a 4-20mA current loop emulator

Enter the first temperature & **Start**  
(In this example, spanned 0-100C, 8mA = 25C)

**G:4-20mA Input**

**Calibrate**

|                  |   |
|------------------|---|
| First value      | 30.11 C   |
| Enter 2nd value  | 50.00   |
| Calibrate 4-20mA | Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> |
| Factory Reset    | Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> |

Calibrate Refresh Cancel

Move the sensor or modify the loop current, entre the 2<sup>nd</sup> temperature & **Calibrate**  
(In this example, spanned 0-100C, 12mA = 50C)

**G:4-20mA Input**

**Calibrate**

|                  |   |
|------------------|---|
| Status           | Calibrated  |
| Enter 1st value  | 50.00 C   |
| Calibrate 4-20mA | Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> |
| Factory Reset    | Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> |

Start Cancel Submit

Status = Calibrated & displays most recent value

**Sensor type = Other**  
Always calibrates.  
Understandably, there are no calibration limits for 'Other' sensors

Cancel to exit & to unlock keypad calibrate access

## AEGIS II Browser

### 5.1 Sensor Calibration: 4-20mA Input Loop Calibration 3 of 3

You'll rarely need to calibrate the underlying 4-20mA current loop.

However, if **Setup** page **Sensor type** = **Other** and **Calibrate** = **2 Point** you can calibrate the underlying 4mA & 20mA levels as follows:

You'll need either a current loop emulator Connected to input 'G' (in this example) or the means to switch the current loop to 4mA & then to 20mA

Set **Calibrate 4-20mA** = **Yes** & **Submit**

Set the current loop @ 'G' to 4mA & **Start**

Set the current loop @ 'G' to 20mA & **Next**

Select **Calibrate** to complete

Status = **Calibrated** on success or error message

The measured 4 & 20 levels are the actual currents at input 'G'.  
If they are not nominally 4 & 20mA, then that may indicate why you are calibrating input 'G' or you may have an emulator problem

**Cancel** to exit & to unlock keypad calibrate access

| G:4-20mA Input   |   |
|--|---|
| Calibrate  |   |
| Enter 1st value  | 50.04 C   |
| Calibrate 4-20mA   | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Factory Reset  | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| <input type="button" value="Start"/> <input type="button" value="Cancel"/> <input type="button" value="Submit"/> |   |

| G:4-20mA Input   |   |
|--|---|
| Calibrate  |   |
| Connect 4mA test   | & Start   |
| Factory Reset  | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| <input type="button" value="Start"/> <input type="button" value="Cancel"/> <input type="button" value="Submit"/> |   |

| G:4-20mA Input   |   |
|--|---|
| Calibrate  |   |
| Connect 4mA test   | 4.00 mA measured  |
| Connect 20mA test  | & Next  |
| Factory Reset  | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| <input type="button" value="Next"/> <input type="button" value="Refresh"/> <input type="button" value="Cancel"/> |   |

| G:4-20mA Input  |   |
|---|---|
| Calibrate   |   |
| Connect 4mA test  | 4.00 mA measured  |
| Connect 20mA test   | 20.00 mA measured   |
| Factory Reset   | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| <input type="button" value="Calibrate"/> <input type="button" value="Refresh"/> <input type="button" value="Cancel"/> |   |

| G:4-20mA Input   |   |
|--|---|
| Calibrate  |   |
| Status   | Calibrated  |
| Enter 1st value  | 100.40 C  |
| Calibrate 4-20mA   | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| Factory Reset  | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| <input type="button" value="Start"/> <input type="button" value="Cancel"/> <input type="button" value="Submit"/> |   |

AEGIS II Browser

5.1 Sensor Calibration:  
5.1.6 Inventory

K:Inhibitor\_Tank

Setup

|                    |   |
|--------------------|---|
| Status             | Reconfigured  |
| Descriptor         | Inhibitor_Tank  |
| Display Units(UOM) | G   |
| Decimal digits     | 2   |
| Disable            | <input type="button" value="Yes"/> <input checked="" type="button" value="No"/> |

Phantom inputs do not physically exist; you can't wire to them. They are of two types: Analog values in the 'K' to 'N' space & volumes-contact sets in the 'W' to 'Z' space. This example, uses 'K' as a tank level

Input 'K' has Compensation set to Inventory

K:Inventory

Configure

|                   |               |
|-------------------|---------------|
| Compensation      | Inventory     |
| O: Tower Make-up  | unused        |
| P: Feedwater      | unused        |
| Q: Tower blowdown | unused        |
| R: Grey Water add | unused        |
| V: Water meter    | unused        |
| Z: Water meter    | unused        |
| 6: Inhibitor Pump | Target Output |
| 8: ORP pid        | unused        |

Inventory subtracts the volume pumped by pulse controls and/or the volume measured by displacement metering on the pump head from the user set volume

In this example, the volume pumped by pulse control '6' lowers the tank level

Phantoms are logged, alarmed & can be used for controls. In this example, likely only a low tank level alarm is used

K:Inventory

Calibrate

Enter value

99.99 G

When the tank is refilled, edit Enter Value & Calibrate to set the current tank level

Cancel to exit & to unlock keypad calibrate access



## AEGIS II Browser

### 5.1 Sensor Calibration:

#### 5.1.7 LSI & Manual Inputs 1 of 2

**L:LSI**

Calibrate

Alkalinity 95 ppm

Factory Reset Yes No

Calibrate Cancel

LSI (Langelier Saturation Index) **Compensation** was selected for phantom sensor input 'L'  
**Calbrate** prompts for those values not measured by the controller

In this example both the pH & conductivity are measured by controller sensors, so only 2 parameters are required to calculate the LSI. (Temperature always measured by the controller)

Measure **Alkalinity**, edit & **Calibrate**

**L:LSI**

Calibrate

CaCO3 Hardness 75 ppm

Factory Reset Yes No

Calibrate Refresh Cancel

Measure **Hardness**, edit & **Calibrate**

Calibration completes.  
LSI recalculated.

**Cancel** to exit & to unlock keypad calibrate access

**L:LSI**

Calibrate

Status Calibrated

Alkalinity 95 ppm

Factory Reset Yes No

Calibrate Cancel

#### Sidebar:

Ryznar Stability Index or 'Ryznar' is a generalized measure of scaling-corrosivity & calculated concurrently from the same parameters & sensors as LSI. The Ryznar value is displayed on the LSI **Diagnostics** page & Ryznar alarms are set on the LSI **Alarms** page

Manual LSI values are clamped to block measure-entry errors;

Alkalinity: 30 to 140 ppm

Hardness: 50 to 400 ppm

Conductivity: 100 to 10,000 uS

pH: 6 -10

If you enter a value outside of the range, the value is set to the closest range limit.

# AEGIS II Browser

## LSI & Manual Inputs 2 of 2

N:Manual Entry

Configure

Compensation

Manual Entry

Reset

Submit

Phantom inputs do not physically exist; you can't wire to them. They are of two types: Analog values in the 'K' to 'N' space & volumes-contact sets in the 'W' to 'Z' space. This example, uses 'N' to log the results of a drop test

Input 'N' has Compensation set to Manual Entry

Phantoms are logged, alarmed & can be used for controls. In this example, the drop test results may be logged so that they can be aligned in time with feed rates & other sensor values

Once Compensation has been set to Manual Entry, rename the Descriptor, Units & digits (after the decimal) to fit your usage

N:Drop\_test

Setup

Descriptor

Drop\_test

Display Units(UOM)

drp

Decimal digits

1

Used by I/O

K,

Reset

Submit

N:Drop\_test

Calibrate

Enter value

8|drp

Factory Reset

Yes

No

Calibrate

Cancel

Edit Enter Value & Calibrate

Cancel to exit & to unlock keypad calibrate access

# AEGIS II Browser

## 5.1.8 CTFS Flowswitch Calibration

A:Conductivity

Configure

Compensation

None

Override flowswitch

☒ Yes ☐ No

Flowswitches

892

Reset

Submit

Select Configure from the Conductivity sensor pulldown

Select Override Flowswitch 'Yes' and press Submit.

A CTFS flowswitch can be adjusted by editing the "Flowswitches" value box in the conductivity Configure menu. Lowsering the value will cause the switch to turn on for a smaller amount of flow but may not turn off the at no flow. Edit this value to be halfway between the on and off value shown on the Diagnostic page.

The "Flow" value shown on the conductivity Diagnostic page shows the current value of the flowswitch. Turn the water on and off to see the high and low values for flow. Edit the Configur/Flowswitches box above to be in the center of these two values. Press the Refresh button to see the current Flow value.

Example: If the flow on value is 1047 with the water running, and 847 when the water is off, the halfway point is 947. Edit the Flowswitches value based on this calculation.

A: Tower Cond.

Diagnostic

| Sensor Type        | Conductivity         |
|--------------------|----------------------|
| Variance this hour | 1449 to 1451 uS      |
| Raw sensor         | 829                  |
| Gain Multiply      | 1.7494               |
| Offset Adjust      | 0.0000uS             |
| Alarmed High       | 18:16:53 2019-Jun-21 |
| Sensor OK          | Connected            |
| 79.7F Flow ON      | Flow:1047 ON @ 892   |

Refresh

## 5.1.9 Corrosion Rate Calibration

B:Corrosion

Configure

Sensor Alloy

Carbon Steel

Carbon Steel

Copper

Cupro-Nickel

Admiralty

Zinc

Other

Reset

Select Configure from the pulldown

A corrosion rate sensor should never be calibrated. Open the Configuration menu and select the Alloy you are using. Press Submit.

Aegis\_II\_Browser.doc

63

## AEGIS II Browser

### 5.2 Sensor Alarms 1 of 2

Select the **A to N** icon on the home page .  
This example is a conductivity sensor connected to input **A**

Select **Alarms** from the pulldown

**A: Tower Conduct.**

|                |   |
|----------------|---|
| HiAlarm        | 2000 uS   |
| LoAlarm        | 1000 uS   |
| Alarm Relay    | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No |
| Delay on Alarm | 5.0 minutes   |
| Disable Alarms | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| Slider Max.    | 4000 uS   |
| Slider Min.    | 500 uS  |

Reset Submit

If using for control, set the **HiAlarm** to trap a fault.  
In this example a failure to bleed-blowdown on an 1800uS setpoint

If using for control, set the **LoAlarm** to trap a fault.  
In this example a stuck float would lower the conductivity towards the make-up conductivity.  
(1800uS & 3 cycles would be a make-up of 600uS)

Set **Alarm Relay = Yes** to trip the output with  
**Special Control = Alarm Relay** on an 'A' alarm

Use **Delay on Alarm** to block nuisance alarms &  
those that occur on transient operating states

**Disable Alarms = Yes** turns OFF 'A' alarms

**Slider Max & Slider Min** are used solely to  
format the browser home page for input 'A'

#### Sidebar:

Every sensor, water meter, flowswitch & each control has alarms.

Typically, alarms are used to trap changes in operating conditions (make-up water, temperature...) mechanical faults (stuck floats, valved off or faulted blowdown-valves), feed issues (loss of prime, low tank level, tubing faults) & sensor faults (failure to track, fouling...)

Setting alarms too tight so that they trip frequently under normal operating variances, may result in a critical alarm getting a slow or no response.

Understandably alarms are set to reflect site practice, chemistry & plumbing & time of year. Review each control loop, its sensor-meter, interlock, pump or actuator & setpoints. It's typical that sensor & feed limit alarms in concert can trip on the most likely faults.

## AEGIS II Browser

### 5.2 Sensor Alarms 2 of 2

LSI alarms differ from other sensor alarms which are limited to high & low alarms referenced to the current value of the sensor.

Sensor high & low alarms & LSI alarms latch. Meaning they persist until **Clear Alarms**.

All unacknowledged alarms flash the red led at the top, right of the controller enclosure cover & appear on the home page on the browser HMI.

Select the **A to N** icon on the home page .  
This example is LSI on phantom input 'L'

Select **Alarms** from the pulldown

Practice varies, but typically any LSI > 0 indicates scaling

Again, opinions vary, but typically Ryznar > 8.0 indicates a corrosive stream

And typically a Ryznar < 6.0 indicates scaling

The LSI & Ryznar levels for alarms vary widely.  
In the absence of guidelines for your water chemistry, metallurgy, exchanger tube type & treatment program, it's you & Wikipedia

Clear Alarms = Yes & Submit resets the alarm on 'L' only

If a sensor has previously alarmed, the most recent alarm type & when it occurred are here.  
LSI displays either **Scale Alarm** or **Corrode Alarm**

LSI & Ryznar duplicate a response on scaling.  
Not surprising since both indexes are derived from the same parameter set.

|  |   |
|--|---|
| L:LSI  |   |
| Alarms   |   |
| Status   | Alarmed   |
| LSI Scaling  | 0.50  |
| RYZ Corrode  | 8.50  |
| RYZ Scaling  | 4.50  |
| Alarm Relay  | <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No             |
| Delay on Alarm   | 5.0 minutes   |
| Clear Alarms   | <input type="button" value="Yes"/>  |
| Scale Alarm  | 10:28 2016-Aug-29   |
| Disable Alarms   | <input type="button" value="Yes"/> <input checked="" type="button" value="No"/> |
| Slider Max.  | 10.00   |
| Slider Min.  | -10.00  |
| <input type="button" value="Reset"/> <input type="button" value="Submit"/> |   |

## AEGIS II Browser

### 5.3 Sensor Setup 1 of 2

Select the **A to N** icon on the home page .  
This example is an ORP sensor connected to input 'D'

Select **Setup** from the pulldown

Edit **Descriptor** to site name for browser & local HMIs.  
Maximum 16 characters

Edit Units, defaults to typical for sensor type  
Maximum 3 characters

#of digits after decimal. Defaults to typical for sensor type  
pH = 2, conductivity = 0

1 Point or 2 Point calibration.  
Defaults to 1 Point, typical for controlling sensors

Submit to modify

Used by I/O blocks the **Disable** option & indicates where the sensor is used.  
Controls 7 & 8 in this example

| D:ORP Sensor       |            |
|--------------------|------------|
| Setup              |            |
| Descriptor         | ORP Sensor |
| Display Units(UOM) | mV         |
| Decimal digits     | 1          |
| Calibrate          | 1 Point    |
| Used by I/O        | 7,8,       |
| Reset              | Submit     |

Select **Configure** from the pulldown to set the **Sensor Alloy** for corrosion rate sensors. Defaults to **Carbon Steel**

If the **Sensor Alloy** pull down does not have the electrode metallurgy you're using, select **Other** & **Submit** (Commonly used metals for cooling towers are in the pull down)

**Alloy#** is the ratio of **Other** electrodes to Carbon Steel (= 1.000) weight loss for LPR type sensors.

| B:Steel Corrosion |              |
|-------------------|--------------|
| Configure         |              |
| Sensor Alloy      | Carbon Steel |
| Reset             | Submit       |

| B:Steel Corrosion |        |
|-------------------|--------|
| Configure         |        |
| Sensor Alloy      | Other  |
| Alloy#            | 1.000  |
| Reset             | Submit |

#### Sidebar:

Disabled sensors do not appear on either the local or browser HMIs or any option pull down.  
Sensors cannot be disabled while in use for control or compensation.  
Disabled sensors are re-enabled on the **System / Enable I/O** page.

## AEGIS II Browser

### 5.3 Sensor Setup 2 of 2

**F:Boiler Cond.**

Setup

|                    |   |
|--------------------|---|
| Descriptor         | Boiler Cond.  |
| Display Units(UOM) | uS  |
| Decimal digits     | 0   |
| Disable            | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Sensor Type        | Boiler Cond.  |

Reset Submit

Select **Setup** from the pulldown to set the type of conductivity sensor connected to a dual conductivity driver card

**Boiler Cond.** are 2 wire, non-temperature compensated.  
**Conductivity** are 4 wire, non-metallic temperature compensated.  
**Condensate** are 4 wire, 3/4" NPT, temperature compensated.

Select **Sensor Type** & **Submit**

**G:4-20mA Input**

Setup

|                    |   |
|--------------------|---|
| Descriptor         | 4-20mA Input  |
| Display Units(UOM) | C   |
| Decimal digits     | 2   |
| Calibrate          | 2 Point   |
| Disable            | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Sensor Type        | Other   |
| 20mA Value         | 100.00 C  |
| 4mA Value          | 0.00 C  |

Reset Submit

**G:CLE3 Chlorine**

Setup

|                    |   |
|--------------------|---|
| Descriptor         | CLE3 Chlorine   |
| Display Units(UOM) | ppm   |
| Decimal digits     | 2   |
| Disable            | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Sensor Type        | CLE3 Chlorine   |
| Sensor Range       | CLE3 0-10ppm  |

Reset Submit

Defined **Sensor Types** may have more than one available **Sensor Range**.  
Select **Sensor Type** & **Submit**  
Then Select **Sensor Range** & **Submit**

4-20mA inputs @ 'G' and on dual 4-20mA input driver cards can select **Sensor Type** = **Other** to install sensor type not shown in the **Sensor Type** pull down

**Sensor Type** = **Other** may set a user defined loop span for the sensor & **Submit**

#### Sidebar:

Selecting a **Sensor Type** installs the correct 4-20 mA to sensor value conversion & sets calibration limits.

## AEGIS II Browser

### 5.4 Sensor Compensation

Select **Configure** from the pulldown to select-view **Compensation**.  
Not all sensor types have **Compensation**

Tower conductivity is always thermally compensated.  
Select **Compensation = Thermal Comp.** & **Submit**.  
Then select **Thermal Sensor = target sensor** & **Submit**

This **Compensation** value works for cooling towers,  
your app may differ

Serial conductivity sensors include a temperature sensor  
(assigned to 'K' in the example) & a thermal flowswitch with  
the option to **Override** the switch flow/no flow trip point

Some amperometric oxidant sensors may be pH corrected.  
Seldom useful for cooling towers where cycle control fixes  
the pH. More useful for process apps where pH varies

Select **Compensation = pH Corrected** & **Submit**.  
Then select **pH Sensor = target sensor** & **Submit**.

**pH Sensor** may be selected = **Manual**  
& **Submit** to get a **Manual pH** entry value

pH temperature compensation is seldom used in Cooling Tower apps  
which operate close to pH 7 where temperature has little effect on pH

Select **Compensation = Thermal Comp.** & **Submit**.  
Then select **Thermal Sensor = target sensor** & **Submit**.

#### Sidebar:

Controllers are typically pre-configured for the target app.  
So cooling tower controllers will include a temperature compensated conductivity.

If you are re-purposing a controller or adding additional sensors & controls then you may be changing-modifying the default compensation.



## AEGIS II Browser

### 5.5 Sensor Diagnostics 1 of 3

Select the **A to N** icon on the home page & the **Diagnostic** page will display

Sensor inputs '**A**' & '**B**' are used for serial sensors

Or select **Diagnostic** from the pulldown

If sensor used for control then **Variance** shows the range of values as the control operates. Reset on the hour.

The sensor value = **Raw sensor** x **Gain** + **Offset**  
Modified in this case by **Thermal Compensation**  
After calibration, **Gain** or **Offset** or both will be adjusted

Most recent alarm type & time-date

Serial conductivity sensors include temperature (**78.1F**) & a thermal flowswitch.  
**Flow 2514** is less than **ON @ 3600** so **Flow OFF**

**A: Tower Conduct.**

**Diagnostic**

| Sensor Type        | Conductivity         |
|--------------------|----------------------|
| Variance this hour | 2542 to 2564 uS      |
| Raw sensor         | 332                  |
| Gain Multiply      | 8.5000               |
| Offset Adjust      | 0.0000uS             |
| Alarmed High       | 14:52:34 2016-Aug-30 |
| Sensor OK          | Connected            |
| 78.1F Flow OFF     | Flow:2514 ON @3600   |

Refresh

Serial sensors auto-install on power ON.  
If you switch types & the previous type was used for control, the control is disabled

Wiring-connection problems flagged here

Attributes which may be assigned to phantoms '**K**' to '**N**' (See Section 5.6) are displayed @ the source sensor I/O location.  
The '**Pitting**' or imbalance value in this example

Some fields are specific to the sensor type.  
In this case the corrosion rate sensor is using Carbon Steel electrodes

**B: Steel Corrosion**

**Diagnostic**

| Sensor Type        | Corrosion            |
|--------------------|----------------------|
| Variance this hour | 11.5 to 11.5 mpy     |
| Raw sensor         | 11.5                 |
| Gain Multiply      | 1.0000               |
| Offset Adjust      | 0.0000mpy            |
| Alarmed High       | 12:08:23 2016-Jul-26 |
| Sensor OK          | Connected            |
| Pitting 0.12mpy    | Carbon Steel         |

Refresh

#### Sidebar:

Diagnostic is a summary of the sensor state.  
Contents vary widely with sensor type.

5.5 Sensor Diagnostics 2 of 3

Select the **A to N** icon on the home page & the **Diagnostic** page will display

Sensor inputs '**C-D**', '**E-F**' and '**I-J**' are used for driver cards so the installed sensor will vary with the type of installed card: pH-ORP, conductivity, 4-20mA input, serial sensor or pH-Temperature

**C:pH Sensor**

Diagnostic

|                    |                      |
|--------------------|----------------------|
| Sensor Type        | pH Sensor            |
| Variance this hour | 8.82 to 8.89 pH      |
| Raw sensor         | 883.00               |
| Gain Multiply      | 0.0100               |
| Offset Adjust      | 0.0000pH             |
| Alarmed High       | 14:52:34 2016-Aug-30 |
| Sensor driver type | Dual pH or ORP       |
| Configure: 103C    | Status: 1007         |
| Device: 000C3A88   | Product: 0E125180    |
| Rev.#: 00000001    | S/N.: 15082008       |
| A.ID#: 31032004    | A.Part#: -1          |
| A.rev#: 0          | Firmware:01.00.02.01 |

Refresh

In this example, there is a pH-ORP card installed in the **C-D** slot & '**C**' is a pH sensor

This pH sensor not used for control or the **Variance** would reflect the control loop delay dependant of feed point, sensor location & re-circ water volume

The sensor value = **Raw sensor** x **Gain** + **Offset**

Most recent alarm type & time-date

Parameters for the **Dual pH or ORP** card installed in the C-D slot

**E:Boiler Cond.**

Diagnostic

|                    |                      |
|--------------------|----------------------|
| Sensor Type        | Boiler Cond.         |
| Variance this hour | 467 to 467 uS        |
| Raw sensor         | 4227                 |
| Gain Multiply      | 0.1000               |
| Offset Adjust      | 0.0000uS             |
| Alarmed Low        | 14:52:34 2016-Aug-30 |
| Sensor driver type | Dual conductivity    |
| Configure: 000C    | Status: FFFFDE5E     |
| Device: 000C3B55   | Product: 0E127777    |
| Rev.#: 00000001    | S/N.: 15082008       |
| A.ID#: 31032004    | A.Part#: -1          |
| A.rev#: 0          | Firmware:01.00.00.02 |

Refresh

The sensor value = **Raw sensor** x **Gain** + **Offset**  
Single point calibration modifies the **Gain** or **Offset** (varies with sensor type)  
Two point calibration modifies both the **Gain & Offset**

Parameters for the **Dual conductivity** card installed in the E-F slot

AEGIS II Browser

5.5 Sensor Diagnostics 3 of 3

Select the **A to N** icon on the home page  
& the **Diagnostic** page will display

G:CLE3 Chlorine

Diagnostic

|                       |                      |
|-----------------------|----------------------|
| Sensor Type           | CLE3 Chlorine        |
| Variance this hour    | 5.80 to 5.84 ppm     |
| Sensor Range          | 0.00 to 10.00 ppm    |
| Raw sensor            | 10.99mA 58.3%        |
| Gain Multiply         | 0.8330               |
| Offset Adjust         | -3.3330ppm           |
| Alarmed High          | 14:52:34 2016-Aug-30 |
| Input Firmware Driver | built-in             |
| Configure: 003C       | Status: 0003         |
| Device: 000C3B40      | Product: 0E120712    |
| Rev.#: 00000001       | S/N:: 15082008       |
| A.ID#: 31032004       | A.Part#: -1          |
| A.rev#: 0             | Firmware:00.00.00.14 |

Refresh

In this example, a 4-20mA **CLE3 Chlorine** sensor is connect to input '**G**'

The user selected **0.00 to 10.00 ppm** CLE3 sensor type converts the 4-20mA signal (**10.99mA** or **58.3%** of span) from the sensor to a ppm value.

In this example  $10.99\text{mA} \times 0.833 - 3.333 = 5.82\text{ppm}$   
(ppm = mA x Gain + Offset)

L:LSI

Diagnostic

|                    |                      |
|--------------------|----------------------|
| Sensor Type        | Calculated           |
| Scale Alarm        | 14:52:34 2016-Aug-30 |
| Ryznar             | 6.4                  |
| Alkalinity         | 95ppm                |
| CaCO3 Hardness     | 75ppm                |
| Temperature        | 89.9F                |
| pH Sensor          | 8.88                 |
| Conductivity       | 2564uS               |
| No source selected |                      |

Refresh

Phantom inputs configured to calculate LSI show Ryznar & the values of the LSI-Ryznar calculation parameters on the Diagnostic page.

K:Temperature

Diagnostic

|                     |                 |
|---------------------|-----------------|
| Sensor Type         | Temperature     |
| Variance this hour  | 77.3 to 173.5 F |
| Raw sensor          | 78.0            |
| Gain Multiply       | 1.0000          |
| Offset Adjust       | 0.0000F         |
| No alarm logged     |                 |
| from A, attribute 1 | Temperature     |

Refresh

Phantom inputs derived from sensor attributes may be independently calibrated modifying the **Gain** or **Offset** value applied to **Raw Sensor**

In this example the **Temperature** is derived from the sensor connected to input '**A**', **attribute 1** (this serial conductivity sensor has 3 attributes)

## AEGIS II Browser

### 5.6 Using Sensor Attributes for Phantoms

Phantom sensors are input 'K' through 'N' and can be enabled from the **System Enable I/O** page.

Once enabled they will automatically appear on the home page for the controller and can be assigned attributes from sensors or used for manual entries and inventory & LSI calculations.

Select the **K** to **N** icon on the home page  
To assign another sensor's attribute to a phantom sensor

Select **Configure** from the pulldown

In this example '**M**' uses attribute '**O**' from sensor '**A**'  
Attribute '**O**' is the raw value of the sensor, conductivity in this example, calibrated to measure salt ppm

Select **Source** = target attribute & **Submit**.  
Pull down has all of the installed sensors & their sensor attributes.

Appendix 'B' lists available attributes by sensor type.

Volume measuring meters have a **Rate** attribute which can be assigned to a sensor.  
In this example the turbine meter @ input '**Q**'s rate is assigned to the phantom @ '**N**'

Select **Source** is not available for phantoms which are used by other sensors.  
In this example the Temperature @ '**K**' is used to temperature compensate the sensors @ '**A**' & '**C**'

**M:Salt\_Concen**  
Configure  
Compensation: None  
Select source: A0: Tower Conduct.  
Reset Submit

**N:Flow rate**  
Configure  
Compensation: Not applicable  
Select source: Q1: Rate  
Reset Submit

**K:Temperature**  
Configure  
Used by I/O: A,C,  
Reset Submit

#### Sidebar:

Phantom Sensors 'K' to 'N' and phantom meters-contact sets 'W' to 'Z' are logged, alarmed & can be used for compensation & controls.

They are phantom in the sense that they do not have wiring locations.

## AEGIS II Browser

### 5.7 Inventory: Using feed meters & pumped volumes

Select the **K to N** icon on the home page  
To make a phantom input track tank volume

Select **Configure** from the pulldown

Select **Compensation = Inventory** & **Submit**

**Inventory** displays all of the volume measuring inputs & pulse controlled pumps.

If using a Tacmina or equivalent displacement meter on an ON/OFF pump, they are typically set to 1mL/pulse.  
If U.S. units, meter scaling = 3785 pulses/G  
If metric units scaling = 1000 pulses / L

Select all of the meters & pumps that use the target tank & **Submit**.  
In this example only the Inhibitor Pump uses the target tank

Initial tank level & tank level on refill is set using **Calibrate**.  
Measured & pumped volumes are subtracted from the **Calibrate** value.

| K:Inventory             |               |
|-------------------------|---------------|
| Configure               |               |
| Compensation            | Inventory     |
| O: Tower Make-up        | unused        |
| P: Feedwater            | unused        |
| Q: Tower blowdown       | unused        |
| R: Grey Water add       | unused        |
| V: Water meter          | unused        |
| Z: Water meter          | unused        |
| 6: Inhibitor Pump       | Target Output |
| 8: ORP pid              | unused        |
| <div>Reset Submit</div> |               |

K:Inventory

Calibrate

Enter value 99.99 G

Calibrate Cancel

#### Sidebar:

Metric or U.S. units are set on the **System / System Setup** page.

The controller converts the pumped mL/stroke setting to either Liters or Gallons depending on the **System Setup metric units = Yes - No** setting.

Volume meters are assumed to measure either Gallons (U.S. units) or Liters (Metric) when calculating **Inventory** - tank levels or ppm concentrations.

Scale all of the volume meters according to the System units setting.

## 6 Measuring Volume: Water Meters, Inventory, Verify Feed

### 6.1 Configuring a New Meter

Select the **O to V** icon from the right side of the home page to configure-setup a new meter or modify an existing meter

Enable new meters @ the **System, Enable I/O** page.  
Enabled as a contact set & appears on right side of home page. See Section 7.1 to switch to meter.

Select **Setup** from the pulldown

Edit **Descriptor** to set site name, 16 characters max. & **Submit**

Edit **Units** (defaults to system units) , 3 characters max. & **Submit**

Select # **digits** after decimal & **Submit**

**Disable** & **Sensor Type** options only display if meter not in use by another I/O

Select **Sensor Type** = **Turbine Meter** (3 wire meters) or **Water Meter** (contact head, 2 wire) & **Submit** to set meter type

**Turbine Meters** are scaled by '**K**'Factor (pulses/gallon)  
Contact head, **Water Meters** are scaled in **Vol/contact** closure.

Select **Sensor Type** = **Turbine Meter** or **Water Meter** controls the type of debouncing used Internally to measure pulse streams or contact closures

In this example, the meter @ '**O**' is used by the control relay '**3**' so **Disable** & **Sensor Type** are not available

## AEGIS II Browser

### 6.2 Copying, Flow Rate Alarms & Rate-to-Volume

**V:Water meter**

Configure

|              |               |
|--------------|---------------|
| Vol/contact  | 100.0 G       |
| Compensation | Copy meter    |
| Target Meter | Z:Water meter |

Reset Submit

Use **Copy Meter** to sum make-up or blowdown volumes from multiple towers or boilers

Select **Compensation = Copy Meter**

Select **Target Meter** = phantom Meter in the 'W' to 'Z' space & **Submit**

This example sums the meter volumes @ 'V' and 'Q' to the phantom meter at 'Z' using **Copy Meter**

**Q: Tower blowdown**

Configure

|              |               |
|--------------|---------------|
| 'K' Factor   | 10.000        |
| Compensation | Copy meter    |
| Target Meter | Z:Water meter |

Reset Submit

**FlowRate Alarm** is used to alarm on high or low flow rate. Disabled when offline or if **Flowswitch** not 'None'

Select **Compensation= FlowRate Alarm** & **Submit**

Then set **High & Low** alarms & **Submit**.  
Set **Low Alarm** < 0 if you don't want a low flow alarm or if flow is not continuous.

**Q: Tower blowdown**

Configure

|              |                |
|--------------|----------------|
| 'K' Factor   | 10.000         |
| Compensation | FlowRate Alarm |
| High Alarm   | 100.0 gpm      |
| Low Alarm    | 50.0 gpm       |
| Flowswitch   | W:Flowswitch_A |

Reset Submit

Alarms do not occur when **Flowswitch** = **OFF**  
Optional: Select a **Flowswitch** & **Submit**

**V:Water meter**

Configure

|                 |                |
|-----------------|----------------|
| Vol/contact     | 100.0 G        |
| Compensation    | Rate to Vol.   |
| Flowrate sensor | G:4-20mA Input |

Reset Submit

Select **Compensation= Rate to Vol** & **Submit**  
Then select a **Flowrate sensor** & **Submit**

Use **Rate to Vol** to convert a 4-20mA input on **Flowrate** to a volume on a meter input.



AEGIS II Browser

6.3 Meter Diagnostics

Select the **O** to **V** icon from the right side of the home page to view the Diagnostic page

Meters display the volume measured from midnight on the home page.

O: Tower Make-up

Diagnostic

|                       |                      |
|-----------------------|----------------------|
| Sensor Type           | Water meter          |
| Vol. this year        | 12600 G              |
| 20 Days Online        | Vol/Day,630 G        |
| Volume Total          | 107500 G             |
| Vol. last year        | 0 G                  |
| Rate                  | 52.8gpm              |
| No alarm logged       |                      |
| Input Firmware Driver | built-in             |
| Configure: 0000       | Status: 0000         |
| Device: 000C4E31      | Product: 0E12519A    |
| Rev.#: 00000001       | S/N:: 15082008       |
| A.ID#: 31032004       | A.Part#: -1          |
| A.rev#: 0             | Firmware:01.01.00.05 |

Refresh

or select **Diagnostic** from the pulldown

Useful if the towers run 7 days/week otherwise discount for typical ON/OFF day ratio

Total since meter installed

Contact head meters calculate **Rate** using the interval since the last volume increase event. Therefore not representative on first count of an new cooling day or first count on a new bleed cycle

Volume resolution (digits after the decimal) is set by **Decimal Digits** on the **Setup** page

Q: Tower blowdown

Diagnostic

|                       |                      |
|-----------------------|----------------------|
| Sensor Type           | Turbine meter        |
| Vol. this year        | 76927.01 G           |
| 20 Days Online        | Vol/Day,3846.35 G    |
| Volume Total          | 798929.50 G          |
| Vol. last year        | 0.00 G               |
| Rate                  | 19.7gpm              |
| No alarm logged       |                      |
| Input Firmware Driver | built-in             |
| Configure: 0001       | Status: 0000         |
| Device: 000C4E31      | Product: 0E12519A    |
| Rev.#: 00000001       | S/N:: 15082008       |
| A.ID#: 31032004       | A.Part#: -1          |
| A.rev#: 0             | Firmware:01.01.00.05 |

Refresh

Turbine type meters calculate **Rate** every second as meter pulse counts are measured. Therefore **Rate** is more representative than contact head meter rates because counting occurs more frequently.

DI (Digital Input) driver detail Shared by all inputs 'O' thru 'V'

Aegis\_II\_Browser.doc

76



6.4 Meter Alarms

Select the **O** to **V** icon from the right side of the home page to view the Diagnostic page

or select **Diagnostic** from the pulldown

**P:Feedwater**

**Alarms**

|                |   |
|----------------|---|
| HiAlarm        | 50000 G   |
| LoAlarm        | 100 G   |
| Alarm Relay    | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Disable Alarms | <input type="radio"/> Yes <input checked="" type="radio"/> No |

Reset Submit

HiAlarm is the volume measured from midnight. Edit & Submit

LoAlarm is set on the daily volume. It's checked only once @ midnight. Edit & Submit

Alarm Relay = Yes & Submit will turn ON the alarm relay if one has been configured.

Disable Alarms = Yes stops new alarms on meter input 'P' in this example.

If alarmed, a **Clear alarms** option will be included on this page.

If you clear a **HiAlarm** & the day has not changed, it will re-alarm because todays volume is more than **HiAlarm**.

In this example, we want an alarm on any **Grey Water** make-up  
But don't want an alarm if there is no **Grey Water** make-up  
(so **LoAlarm** is less than zero)

In this example, we're also using one of the relays or pulse outputs as a dedicated alarm relay, perhaps to the site DCS.

**R:Grey Water add**

**Alarms**

| Status         | Adjusted Alarm  |
|----------------|---|
| HiAlarm        | 10.00 G   |
| LoAlarm        | -100.00 G   |
| Alarm Relay    | <input checked="" type="radio"/> Yes <input type="radio"/> No |
| Disable Alarms | <input type="radio"/> Yes <input checked="" type="radio"/> No |

Reset Submit

7 Flowswitches, Interlocks & Contact Sets

7.1 Switching Meters & Contact Sets

Volume meters and contact set inputs are connected in the ‘O’ to ‘V’ namespace. They are also in the ‘W’ to ‘Z’ phantom space. If the meter or contact set input is not being used for control, it can be re-purposed, making a contact set a meter or the reverse.

When an input in the ‘O’ to ‘Z’ namespace is enabled, it’s initially configured as a contact set.

Contact sets are ON when the contact set is closed. The logical sense of the input may be inverted so that ON = contact set open (Refer to Section 7.3).

Select the **O** to **V** icon from the right side of the home page

U:Low\_Level

Setup

|             |   |
|-------------|---|
| Descriptor  | Low_Level                                 |
| Disable     | <div>Yes</div> <div>✓</div> <div>No</div> |
| Sensor Type | Contact set                               |

Reset

Submit

Select **Setup** from the pulldown

Select **Sensor Type** from the pulldown  
Water meter = 2 wire contact head meter  
Turbine meter = 3 wire pulse meter  
& Submit

Changing the DI (digital input) type using **Sensor Type** is not available if the DI is in use by a control, interlock, fail-to-feed...

In this example, **Used by I/O** indicates that **S:Flowswitch** is used by the control for relays **1 & 3**. (likely as an interlock flowswitch)

S:Flowswitch

Setup

|             |            |
|-------------|------------|
| Descriptor  | Flowswitch |
| Used by I/O | 1,3,       |

Reset

Submit

## AEGIS II Browser

### 7.2 Contact Set Alarms

Select the **O** to **V** icon from the right side of the home page

Select Alarms from the pulldown

In this example, if the flowswitch is ON for more than 10 hours it will alarm. Edit & **Submit** to modify

The **No Flow Alarm** is set to > 1440 (the number of minutes in a day) so it will never alarm.

Alarms use the time ON or OFF today which is reset to 0.0 @ midnight.

| S:Flowswitch   |   |
|--|---|
| Alarms   |   |
| ON Time Alarm  | 600.0 minutes   |
| No Flow Alarm  | 1500.0 minutes  |
| Alarm Relay  | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Disable Alarms   | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| <input type="button" value="Reset"/> <input type="button" value="Submit"/> |   |

If you are not using the alarms, set **Disable Alarm = Yes** & **Submit**

In this example, we're using the alarm to alert us if the cooling tower is offline for more than an hour. Edit & **Submit** to modify

| S:Flowswitch   |   |
|--|---|
| Alarms   |   |
| ON Time Alarm  | 1500.0 minutes  |
| No Flow Alarm  | 60.0 minutes  |
| Alarm Relay  | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Disable Alarms   | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| <input type="button" value="Reset"/> <input type="button" value="Submit"/> |   |

#### Sidebar:

Contact set alarms are frequently used to flag unusual operating conditions or outages.

If you are alarming on an event that bridges midnight, bear in mind that the ON or OFF time that trips the alarm is reset @ midnight.

### 7.3 Logically Inverting Contact Sets

Select the **O** to **V** icon from the right side of the home page

Select **Configure** from the pulldown

If you are interlocking using a contact set that is OPEN in the interlocked state, **Invert sense** & input 'T' will be ON when the contact set is open

Set **Invert sense** = Yes & **Submit**

| T:Boiler 1 OnLine                    |   |
|--------------------------------------|---|
| Configure                            |   |
| Compensation                         | None  |
| Invert sense                         | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Used by I/O                          | 4,  |
| <input type="button" value="Reset"/> | <input type="button" value="Submit"/>                         |

### 7.4 Fail-to-Feed

Fail-to-Feed alarms on the contact set input that monitors the pump head feed meter if measured feed events do not occur every **Delay on Alarm** period while the pump is ON.

In this example **U:Monitor Feed** would display a '**Fail to Feed**' alarm if a feed contact closure did not occur every 30 seconds or less while Relay 3 is ON, unless 'U' alarms were disabled.

If you wire the feed verify meter in parallel to a volume meter input, you can measure the actual volume fed.

Select the **O** to **V** icon from the right side of the home page

Select **Configure** from the pulldown

Set **Compensation** = Fail to Feed & **Submit**

Then select **Target Output** = target control and **Delay on Alarm** = time between measured feed volume pulses & **Submit**

**Fail-to-feed** uses a meter on the output of the pump like those made by Tacmina, which measure volumes in the mL range. Depending on the pump size, there will be a delay between turning ON the pump & measuring the first & subsequent feed pulses.

| U:Monitor_feed                       |   |
|--------------------------------------|---|
| Configure                            |   |
| Compensation                         | Fail to Feed  |
| Target Output                        | 3:Inhibitor Feed  |
| Delay on Alarm                       | 30 seconds  |
| Invert sense                         | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| <input type="button" value="Reset"/> | <input type="button" value="Submit"/>                         |

## AEGIS II Browser

### 7.5 Mirroring a Control ON/OFF

A phantom contact set may be configured to mirror a relay (1-5) or a pulse output (6-9) configured as an ON/OFF control. When the control is ON, the phantom contact set is ON.

This compensation is available to link controls when simply wiring them in parallel wouldn't work.

#### For example:

Site doesn't have a bleed meter installed but needs to feed into the bleed line whenever the bleed is ON (perhaps a de-chlor or a sequestrant for a component that's concentrated when the tower cycles up).

Relay 1 controls the bleed on conductivity

Pulse 8 feeds the bleed line chemical, configured to base feed @ 5mL/minute

Phantom Contact Set 'X' mirrors Relay 1 & Interlocks Pulse 8

When done with **Mirror output** (instead of simply using conductivity to control Pulse 8) any blocking or Prebleed-Lockout that stops Relay 1, stops feeding into the bleed line.

The screenshot shows the configuration interface for a Phantom Contact Set. The interface is titled "X:Contact set" and has a "Configure" button. Below this, there are four configuration fields:

- Compensation:** A dropdown menu showing "Mirror output".
- Target Output:** A dropdown menu showing "1:Tower276 Bleed".
- Invert sense:** Two radio buttons, "Yes" and "No", with "No" selected.
- Sensor Type:** A dropdown menu showing "Contact set".

At the bottom of the form are "Reset" and "Submit" buttons. Green callout boxes with arrows provide instructions:

- Top left: "Select the W to Z icon from the right side of the home page" (pointing to the "X:Contact set" header).
- Top right: "Select **Configure** from the pulldown" (pointing to the "Configure" button).
- Middle right: "Select **Compensation** = **Mirror output** & **Submit**" (pointing to the "Compensation" dropdown).
- Bottom right: "Then select **Compensation** = **Target Output** & **Submit**" (pointing to the "Target Output" dropdown).

## 8 Frequency Controlled Pumps

### 8.1 Selecting a Pump, Adjust mL/stroke & SPM

Select the '6' to '9' icon from the right side of the home page

Select **Configure** from the pulldown

**6:Inhibitor Pump**

**Configure**

**Status** Reconfigured

**Descriptor** Inhibitor Pump

**Disable** Yes ☐ No ☒

**Pump Type** ProMinent 1602

**mL/stroke** 0.130

**Refresh** **Submit**

**Pump Type** sets limits on mL/minute setpoints

Set **Pump Type** = one of the 6 built-in pumps & **Submit**  
Setting both the maximum SPM & typical 40 psi head feed rate

Use the default **mL/stroke** unless:  
1. You require the accuracy the you would get from calibrating with a graduated cylinder.  
2. The pump is not @ 100% stroke.

Be aware that the output of most pumps will vary when backpressure changes. Using a back pressure valve will hold that pressure steady.

Select **Pump Type** = **Other** for larger pulse-frequency controlled pumps & **Submit**

Edit **mL/stroke** & **Rated SPM** for the installed pump & **Submit**  
'Other' type pumps are limited to 25 **mL/stroke**.  
Listed pumps are limited to 2.0 **mL stroke**.  
All have no minimum limit.

Exercise care not to exceed the Rated SPM for the pump, response to high pulse rates is indeterminate and maximum feed rates will be incorrect.

**9:Dispersant**

**Configure**

**Descriptor** Dispersant

**Disable** Yes ☐ No ☒

**Special Control** None

**Pump Type** Other

**mL/stroke** 5.000

**Other Pump** 400 Rated SPM

**Refresh** **Submit**

#### Built-in Pump types

| Pump Type | mL/stroke | Liters/hr | Gallons/hr |
|-----------|-----------|-----------|------------|
| 1601      | 0.13      | 1.404     | 0.371      |
| 1602      | 0.24      | 2.592     | 0.685      |
| 1001      | 0.10      | 1.080     | 0.285      |
| 1002      | 0.24      | 2.592     | 0.685      |
| 0704      | 0.42      | 4.536     | 1.198      |
| 0705      | 0.50      | 5.400     | 1.427      |

## 9 4-20mA Outputs

### 9.1 Configure: Manual-Auto Switch

Select the letter icon from the bottom right side of the home page

A newly installed 4-20mA out card initializes to Manual mode & 0% (4mA) output current

Select **Configure** from the pulldown

Select **Control by:** and the target control sensor from the pull down & **Submit**

Edit **Manual mode** level & **Submit** to modify the current.  
0.0% = 4 mA 100% = 20 mA

(Optional) When the Interlocked contact set input is OFF, the current is set to 4mA  
Set **Interlocked** = target contact set & **Submit**

**I:4-20mAOutput**

**Configure**

Control by: **None**

Manual mode ☒ Yes ☐ No

Manual mode **47.6 %**

Interlocked **none**

Open Loop alarm ☒ Yes ☐ No

Controls a Pump ☐ Yes ☒ No

Reset Submit

**J:4-20mAOutput**

**Configure**

Control by: **pH Sensor**

Manual mode ☒ Yes ☐ No

Manual mode **25.0 %**

Interlocked **S:Flowswitch**

Open Loop alarm ☒ Yes ☐ No

Reset Submit

Exit Manual to Auto mode by **Manual mode = No & Submit**

Controls a Pump = Yes goes to 4mA when **STOP** key pressed

In Auto mode, edit both **20mA Value & 4mA Value & Submit**

**J:4-20mAOutput**

**Configure**

Control by: **pH Sensor**

Manual mode ☐ Yes ☒ No

20mA Value **10.00 pH**

4mA Value **6.00 pH**

Interlocked **S:Flowswitch**

Open Loop alarm ☒ Yes ☐ No

Reset Submit

In this example, a pH of 7.5 would set the 4-20mA output to 10mA  

$$(16\text{mA} \times (7.5 - 6.0) / (10.0 - 6.0)) + 4\text{mA}$$

#### Sidebar: Manual Mode

Use **Manual mode** to verify the pump is 100% ON=20mA, completely OFF=4mA. and to verify the loop span on the monitoring DCS that is using the current loop value to represent a controller conductivity, pH, ORP, corrosion rate sensor or ppm calculation.

9.2 Adding Special Control to 4-20mA Outputs

6:Acid Control

Setup

|               |                |
|---------------|----------------|
| Control Type  | Feed           |
| Mode          | Pulse Output   |
| Set Feed Mode | Sensor Control |
| Control by:   | E:pH Sensor    |

Refresh

Submit

Select a frequency pump 6 through 9. If not available, enable one. Only Relays 6 through 9 will work

Set up the relay Control Type as Feed and based on the sensor of choice

Must use the Pulse Output choice

Set up the Configure, alarm and setpoint menus as needed. Close the relay menu window when done

Open the 4-20mA output menu. Use the Setup menu to edit the output name/description.

I:Acid pump speed

Configure

|                 |                                |
|-----------------|--------------------------------|
| Control by:     | Acid Control                   |
| Manual mode     | <div>Yes</div> <div>✓ No</div> |
| 20mA Value      | Rated SPM                      |
| 4mA Value       | OFF                            |
| Interlocked     | S:Flow switch                  |
| Open Loop alarm | <div>Yes</div> <div>✓ No</div> |
| Controls a Pump | <div>✓ Yes</div> <div>No</div> |

Reset

Submit

Use the Configure menu to set the Control by. The pulse output relay will be identified by the relay name. My relay 6 is named Acid Control so I chose it here.

Switch to Manual mode to test the output

The 4 and 20mA output values are driven by the relay and cannot be adjusted here. Set the Interlock here or in the relay.

The Open Loop alarm choice will alarm this output if the 4-20mA wires are not connected correctly. With Controls a Pump set to YES, the output will drop to 0% if the STOP button is pressed on the controller panel or if the Control By is set to a relay.



9.3 Calibrate a 4-20mA Output

Select the letter icon from the bottom right side of the home page

Select **Calibrate** from the pulldown

Calibrate overrides the Manual setting or sensor control to set the output to 4mA & then 20mA

Select **Start** to start the two point calibration process

Edit **Output @ 4mA** level & select **Calibrate**

Use the mA current value displayed on the pump, measured by the DCS or meter

Edit **Output @ 20mA** level & select **Calibrate**

**Factory Reset = Yes & Submit**  
Returns the 4-20mA outputs to default

Calibration ends.  
Select **Cancel** to return the current loop to Manual or sensor control & exit calibration

| J:4-20mAOutput      |         |
|---------------------|---------|
| Calibrate           |         |
| 4-20mA = 4mA        | ✓ START |
| Factory Reset       | Yes No  |
| Start Cancel Submit |         |

| J:4-20mAOutput           |      |
|--------------------------|------|
| Calibrate                |      |
| Output @ 4mA             | 3.95 |
| Calibrate Refresh Cancel |      |

| J:4-20mAOutput           |       |
|--------------------------|-------|
| Calibrate                |       |
| Output @ 20mA            | 19.86 |
| Calibrate Refresh Cancel |       |

| J:4-20mAOutput      |            |
|---------------------|------------|
| Calibrate           |            |
| Status              | Calibrated |
| 4-20mA = 4mA        | ✓ START    |
| Factory Reset       | Yes No     |
| Start Cancel Submit |            |

9.4 Diagnostic & Mirroring

Select the letter icon from the bottom right side of the home page to display **Diagnostic** page

J:4-20mAOutput

Diagnostic

|                    |                      |
|--------------------|----------------------|
| Sensor Type        | 4-20mAOutput         |
| Control by:        | pH Sensor            |
| Gain Multiply      | 1.0057               |
| Offset Adjust      | 0.0031mA             |
| Sensor driver type | Dual 4-20mA Output   |
| Configure: 003C    | Status: 0000         |
| Device: 000C3A55   | Product: 0E125188    |
| Rev.#: 00000001    | S/N: 15082008        |
| A.ID#: 31032004    | A.Part#: -1          |
| A.rev#: 0          | Firmware:00.00.00.01 |

Refresh

Or select **Diagnostic** from the pulldown

Controlling sensor name

Gain & Offset are modified when a 4-20mA output is calibrated.  
Factory Reset: **Gain** = 1.0 & **Offset** = 0.0

**Mirroring a Pulse Controlled Pump**  
If you select a pump to control the 4-20mA output from the **Control by:** pull down  
The 4-20mA output is automatically spanned  
4mA = 0 SPM to 20mA = 100% SPM.  
  
Mirroring provides a way to implement more complex controls on a 4-20mA output or to monitor pump speed on a DCS

I:4-20mAOutput

Diagnostic

|                    |                      |
|--------------------|----------------------|
| Sensor Type        | 4-20mAOutput         |
| Manual Setpoint    | 12.96mA 56.0%        |
| Gain Multiply      | 1.0000               |
| Offset Adjust      | 0.0000mA             |
| Sensor driver type | Dual 4-20mA Output   |
| Configure: 033C    | Status: 0000         |
| Device: 000C3A55   | Product: 0E125188    |
| Rev.#: 00000001    | S/N: 15082008        |
| A.ID#: 31032004    | A.Part#: -1          |
| A.rev#: 0          | Firmware:00.00.00.01 |

Refresh

4-20mA in **Manual mode**  
Shows both loop current & % of span  
(for loops controlling pumps)

4-20mA Output driver detail  
Shared by inputs 'I' & 'J'

10 System Settings

10.1 Home & Diagnostic pages

Select the controller icon at the top of the home page to access the **System** menu.

System:

Home

|              |                                    |
|--------------|------------------------------------|
| 2019-Jun-13  | S/N:2017057141                     |
| Status       | Logged in                          |
| Current User | admin                              |
| Logout       | <input type="button" value="Yes"/> |

Reset

Submit

Date and controller serial number

Current Log on state and user

Logout here or on the home page.  
Logs out automatically if no activity for "Browser Logout" minutes. See System Setup for minutes selection.

System: Diagnostic

Diagnostic

|                         |             |
|-------------------------|-------------|
| Serial number           | 2017057141  |
| Firmware                | 19.05.29.00 |
| HMI Firmware            | 16.07.11.00 |
| Web Browser HMI Version | 11.00.00.00 |
| Relay Fuse              | OK          |
| Watchdog Resets         | 4           |
| Admin Password          | Default     |
| O-T wiring              | OK          |
| U-V wiring              | OK          |
| Fan speed               | 4020 RPM    |
| Biotiming, Events       | Thu, WEEK 1 |

Refresh

Select Diagnostic from the pulldown

Controller serial number

Firmware versions

Relay fuse status

Accumulates CPU crashes. Should read O. Check incoming power.

Default = AAAA, otherwise known only to the Admin

Power status for 3 wire inputs 'O' thru 'T'.

Power status for 3 wire inputs 'U' and 'V'. U and V have a separate power supply from O – T.

Cooling fan fault shuts down all sensor driver cards & controls. Displays only fault message on local HMI display

Events are entered as daily, weekly or monthly (28 days). In daily, every day is day = 1. In weekly, every Sunday is Sunday = 1. This page shows the 28 day cycle.

AEGIS II Browser

10.2 Activity Log:  
10.2.1 User ID, time stamp

System: Activity Log

Select **Activity Log** from the **System** pulldown

Activity Log

82 Events, 41-50

Initially displays the current day's activities in blocks of 10

Sep

1

View another day: Select Month & Day then press **Submit**  
(Last six months selectable)

| IO | Activity                 | User ID | Time     |
|----|--------------------------|---------|----------|
| A: | Alarms Alarmed High      | System  | 12:38:01 |
| C: | Alarms Alarmed High      | System  | 12:38:01 |
| E: | Alarms Alarmed Low       | System  | 12:38:01 |
| F: | Alarms Alarmed Low       | System  | 12:38:01 |
| L: | Alarms Scale Alarm       | System  | 12:38:01 |
| M: | Alarms Alarmed High      | System  | 12:38:01 |
| S: | Activity Adjusted Alarm  | admin   | 12:38:52 |
| U: | Activity Changed         | admin   | 13:40:30 |
| U: | Activity Changed         | admin   | 13:40:41 |
| U: | Configure Compen. modify | admin   | 13:41:04 |

The list shows the I/O point effected, a description of the activity, the User that made the change and the time

List activities both by **User ID** & those that occur Automatically (**System**).

In these examples, the System logs input M is Alarmed & the admin user adjusted the Alarms on Input 'S'

Next

Back

Submit

Next button is removed when at end of list.  
In this example, we are viewing events **41-50** of **82** total activities

If you select a day when the controller was powered OFF or prior to it's installation, you'll get this response

System: Activity Log

Activity Log

0 Events, 1-0

May

1

No activity file

Submit

## AEGIS II Browser

### 10.3 Communications: 1 of 2

#### 10.3.1 LAN IP, Netmask, MAC, Gateway, Wifi IP

You'll need to be logged in as the admin user to modify **Communications**.

The top of the page will prompt you with the required login if you are not allowed to modify the current page.

The controller includes a **DHCP client** which means when you connect to the site LAN you can assign a static IP valid for the LAN or select DHCP and let the network assign a compatible IP address to the controller.

The screenshot shows the 'System: Communications' settings page. The 'System' dropdown is set to 'Communications'. The 'Communications' section contains the following fields:

- LAN IP Address:** 10.10.6.140. Callout: 'Current IP LAN address of the controller. If you edit & Submit to modify, you'll lose the current browser connection. Re-connect using the new IP address.'
- DHCP:** Radio buttons for 'Yes' and 'No' (selected). Callout: 'Select DHCP if you wish the system to choose the IP address. This ensures the controller is visible from and compliant with the customers network.'
- LAN Netmask:** 255.255.255.0. Callout: 'Set LAN Netmask to desired netmask & Submit'.
- LAN MAC Address:** 00:1e:c0:ef:42:ab.
- LAN Gateway:** 10.10.6.19. Callout: 'If you are using the E-mail functionality (alarms & auto-reporting), then the LAN Gateway should match other devices on this LAN'.
- LAN Primary DNS:** 10.10.6.19.
- LAN Secondary DNS:** 0.0.0.0. Callout: 'Set the WiFi for always on, off or for 5 minute timeout after using. Some customers do not want the WiFi signal.'
- WiFi Controls:** Dropdown menu set to 'WiFi while used'. Callout: 'Controller WiFi is limited to HTTP browser services for mobile devices & notebook WiFi & therefore uses a fixed IP address. With the SSID set on the System Setup page'.
- WiFi IP Address:** 192.168.1.1.
- WiFi Netmask:** 255.255.255.0.
- WiFi SSID:** \_AegisII\_141. Callout: 'The WiFi SSID defaults to \_AegisII\_xxx where xxx = last 3 numbers of the controller serial number. If multiple controllers in close proximity, edit to create descriptive ID like "Boilers" etc. & Submit'.
- HTTP Port:** 80. Callout: 'The HTTP port is defaulted to 80, the standard browser port'.

Buttons at the bottom: 'Reset' and 'Submit'.

#### Sidebar:

If you modify the IP or Netmask & can no longer connect, the current IP & Netmask can be viewed on the local HMI (keypad & display).

Key **Menu / Up / System / OK / Communication / OK & Up** - Down to scroll through the settings.

LAN (Local Area Network) refers to the Ethernet port connection. WiFi refers to the wireless connection. See section 1.1 for connection information.

# AEGIS II Browser

## Communications: 2 of 2

### 10.3.2 Com card setup

The communication card adds the option of communicating with a wide range of standard equipment protocol. This card includes a serial slave port for connection with a plant serial MODBUS, or a variety of Gateways for access to MODBUS TCPIP, serial or IP BACnet or most any protocol with the proper Gateway.

The communication card includes two 4-20mA outputs while allowing a dual 4-20mA input card to be piggy-backed on the com card.

The Pyxis fluorometer is compatible with the MODBUS Master serial port while a serial Master can attach to the serial Slave port. The second slave port can be used to pass along the Master communication.

Consult the Addendum: Aegis II Communication Driver manual for complete instructions.

Note: The below picture is the lower part of the System: Communications menu from the previous page.

|                                    |                       |   |
|------------------------------------|-----------------------|---|
| Pyxis connected                    | No                    | Pyxis Fluorometer status  |
| Modbus Slave                       | RTU Serial Connection | Slave port status   |
| RTU address                        | 10                    | Serial MODBUS setup.<br>Port number must be unique to the network<br>The baud rate, parity and stop bit settings must match the Master port |
| RTU Baud rate                      | 19200                 |   |
| RTU parity                         | EVEN                  |   |
| RTU stop bits                      | ONE                   |   |
| <div>Reset</div> <div>Submit</div> |                       |   |

10.4 E-Mail Setup – Test

System: E-mail Setup

E-mail Setup

Status

Mail error: 503

E-mail Enabled

Yes

No

H2Tronics eService Report

Yes

No

E-mail Data Log

at Midnight

E-mail on Alarm

Yes

No

E-mail Status

at Midnight and 12:00PM

Mail To:

Unassigned

cc E-mail to

Unassigned

cc E-mail to

Unassigned

cc E-mail to

Unassigned

cc E-mail to

Unassigned

E-mail Enabled = Yes sends a daily E-mail @ noon so you know the controller is up. Sensor values confirm control. E-mail services enable.

E Service Reports requires a paid subscription to H2Tronics.

E-mail Daily Data Log= Yes sends a midnight E-mail. Includes sensor values, run times, volumes.... Targeted @ apps that parse E-mail body for content

E-mail on Alarm = Yes sends an E-mail on alarm. Includes sensor values & volumes so you get operating context

Choose E-mail status: Disable, Midnight, Noon and Midnight & Noon Includes sensor values & volumes so you get operating context.

Edit Mail To = your email & Submit

Edit to add 3 optional cc E-mail to & Submit

Continued on next page

# AEGIS II Browser

Continued from previous page

|   |   |   |
|---|---|---|
| SMTP IP Address   | <input type="text" value="43.228.184.6"/>                                       | <p>Shown are the default SMTP settings that point to the Prominent SMTP server. This is a free service. If you cannot use the service, enter your service information and press Submit.</p> |
| SMTP Port   | <input type="text" value="2525"/>   |   |
| SMTP Username   | <input type="text" value="aegis@prominent.us"/>                                 |   |
| SMTP Password   | <input type="password" value="...."/>   |   |
| SMTP reset  | <input type="button" value="Yes"/> <input checked="" type="button" value="No"/> | <p>Reset the SMTP setting to those shown on this page</p>   |
| Test E-mail   | <input type="button" value="Yes"/> <input checked="" type="button" value="No"/> | <p>Send a status report to all email addresses listed above</p>   |
| Next mail   | <input type="text" value="2.15hrs"/>  | <p>Next report is expected to send ...</p>  |
| <div><input type="button" value="Reset"/> <input type="button" value="Submit"/></div> |   |   |



## AEGIS II Browser

### 10.5 Time & Date:

#### 10.5.1 Sync to Device

The screenshot shows the 'System: Time & Date' configuration page. At the top, a dropdown menu is set to 'Time & Date'. Below this are three input fields: 'Date DD/MM/YY' with the value '02/09/16', 'Time HH:MM:SS' with the value '11:13:55', and 'Weekday' with a dropdown menu showing 'Fri'. A link labeled 'Set fields to match my computer' is positioned above 'Reset' and 'Submit' buttons. Green arrows point from callout boxes to these elements: one to the system dropdown, three to the Date, Time, and Weekday fields, one to the 'Set fields to match my computer' link, and one to the 'Submit' button.

**System: Time & Date**

Select **Time & Date** from the **System** pulldown

**Time & Date**

|               |          |
|---------------|----------|
| Date DD/MM/YY | 02/09/16 |
| Time HH:MM:SS | 11:13:55 |
| Weekday       | Fri      |

[Set fields to match my computer](#)

Reset Submit

Edit the **Date**, **Time** & **Weekday** fields & **Submit**  
Follow the formatting for the **Date** (DD/MM/YY)  
and **Time** (HH:MM:SS) fields  
or you'll get an error message  
or use the [Set fields...](#) link

Adjusting the time & date affects biocide feed events,  
controls that use time, data logging, alarming.....

This is usually the easiest way to synch the controller to  
your device, click on the link & **Submit**.

## AEGIS II Browser

### 10.6 Enable I/O:

#### 10.6.1 Enable IO, Assign to System#

##### Sidebar:

If you select **two systems** (System Setup menu), you will see the menu on the left. A **single system** user will see the menu in the lower right corner of this page.

All I/O points can be enabled and used in the program. Enabled points are displayed on the main screen. If a point is disabled, it is removed from the main screen and has no programmable function.

**Enable I/O**

Select **Enable I/O** from the **System** pulldown

**Enable I/O**

Configure **Control**

1: Tower276 Bleed **Shared**

2: Oxidant\_Control **Shared**

3: Inhibitor Feed **Shared**

4: Boiler\_1\_CS **Shared**

5: Sensor\_Wash **Shared**

6: Inhibitor Pump **Boiler\_System**

7: ORP\_ONOFF **Tower\_System**

8: ORP pid **Shared**

9: Dispersant **Shared**

**Enable I/O** **Y:Contact set**

Reset Submit

The Configure box allows you to see all Sensors, Meter/Contacts or Control relays. This example shows all Control relays. Edit this choice to see Sensors or the Meter Contact lists.

If the **System Setup** page field **# of Systems** = **Two**, this page allows you to select to which system the I/O pertains.

System Setup page field **# of Systems** = **One**  
Is limited to **Enable IO** as there are not systems to designate.

Select I/O you wish to enable or **None** & **Submit**

**Enable I/O**

**Enable I/O**

**One System** **No View-Config**

**Enable I/O** **Y:Contact set**

Reset Submit

## AEGIS II Browser

### 10.7 System Setup:

#### 10.7.1 Naming, Sunday=Day1 ,Metric Units, Restart Options

You'll need to be logged in as the admin user to modify **System Setup**.

The top of the page will prompt you with the required login if you are not allowed to modify the current page.

**System Setup**

Select **System Setup** from the **System** pulldown

|                    |   |
|--------------------|---|
| Status             | Reconfigured  |
| Site name          | ProMinent   |
| System-Name        | CT1   |
| 2nd System-Name    | CT2   |
| Keypad Password    | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Metric Units       | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| # of Systems       | Two   |
| Logging rate       | 5 Minutes   |
| Browser logout     | 60 Minutes  |
| Alarm on STOPS     | <input checked="" type="radio"/> Yes <input type="radio"/> No |
| System restart     | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Factory Reset      | <input type="radio"/> Yes <input checked="" type="radio"/> No |
| Enable Alarm Chime | <input type="radio"/> Yes <input checked="" type="radio"/> No |

Reset Submit

**Site Name & System-Names** will tag your reports & E-mail alarms to differentiate controllers. Sixteen characters maximum. Edit & Submit

Select **Keypad Password = Yes** & Submit  
Shares passwords & access level with browser users, see Section 10.7

**Metric Units = Yes** & Submit displays temperatures in 'C' & measures volumes in Liters.  
**Metric Units = No** & Submit displays temperatures in 'F' & measures volumes in Gallons

Select # of Systems = One or Two & Submit  
Two turns on selectors in Enable I/O page

Logging rate set the frequency of data points stored in the database

Browser logout will end the browser session after x minutes of inactivity

Select **Alarm on STOPS = Yes** & Submit  
To alarm when user presses STOP on local HMI keypad.

Select **System restart = Yes** & Submit  
Same effect as cycling the power OFF-ON; restarts controls & actuation times

Select **Factory Reset = Yes** & Submit  
Removes user settings, controls, naming, calibration...  
Load a default or previously saved configuration after **Factory Reset** to avoid reconfiguring each I/O.

Select **Enable Alarm Chime = Yes** & Submit  
for audible tone on alarm

## AEGIS II Browser

### 10.8 Passwords: 1 of 2

#### 10.8.1 View-Set Access Level - Admin

The System Passwords screen allows users to change their passwords.

The Passwords screen seen by the Admin user is different from the other users. This page describes the Admin version. The next page explains the Users version.

Changes made on these pages are logged in the Activity Log.

The screenshot shows the 'System: Passwords' interface. At the top is a title bar 'System: Passwords' with a close button. Below it is a dropdown menu currently showing 'Passwords'. The main area contains several fields and buttons:

- Status:** A text field showing 'Login @ Admin'.
- New Password:** A text input field containing 'AAAA'.
- Confirm Password:** A text input field containing 'AAAA'.
- admin:** A text field showing 'View-Set Access'.
- Select User:** A dropdown menu showing 'O:Operator1'.
- Access Level:** A dropdown menu showing 'Operate'.
- Reset user password:** A section with three buttons: 'Yes', '✓' (selected), and 'No'.
- Buttons:** 'Reset' and 'Submit' buttons at the bottom.

Annotations with arrows point to various elements:

- An arrow points to the 'Passwords' dropdown menu with the text: 'Select **Passwords** from the **System** pulldown'.
- An arrow points to the 'Status' field with the text: 'Shows the user or lets you know you need to be logged in as Admin if a user attempts to perform a function that is not allowed at their access level'.
- Two arrows point to the 'New Password' and 'Confirm Password' fields with the text: 'In this section, any user can change their password. Edit the passwords in both boxes & press **Submit**. In this example, the default **Admin** password is shown.'
- Two arrows point to the 'Select User' and 'Access Level' dropdowns with the text: 'This section is only available to the Admin user: Select a user, choose an Access Level and press Submit.'
- An arrow points to the 'Reset user password' section with the text: 'The 'Operate' Access Level is used to prevent casual users from inadvertently modifying controls.'
- A large box at the bottom contains the text: 'This function can only be performed by the Admin user. Although, each user can always change his/her own password, the Admin user can also reset other user passwords to their default. Select a user, press **Reset user password** and then press **Submit**. This button does not affect the Admin password.'

#### Default Passwords:

Operator1 = 1 Operator2 = 2 Operator3 = 3 Operator4 = 4.

Configure5 = 5 Configure6 = 6 Configure7 = 7 Administrator = AAAA

**Login Page:** Operators can view all controller pages. No access to most System pages.  
Configure users can edit the program. No access to most System pages.

#### Modify Passwords:

If the controller is accessible on the site LAN, you should modify all 8 passwords.

Two users cannot share the same password because only the password is used to identify keypad users. The controller displays **Password Fail** on a duplicate password.

# AEGIS II Browser

## Passwords: 2 of 2

### 10.8.2 View-Set Access Level - Users 1 - 7

System: Passwords

Passwords

|                  |                 |
|------------------|-----------------|
| Status           | Login @ operate |
| User ID          | Operator1       |
| New Password     | ..              |
| Confirm Password | ..              |

Reset

Submit

Select Passwords from the System pulldown

Shows Access Level

The 'Operate' Access Level is used to prevent casual users from inadvertently modifying controls.

Displays User name. Edit and press Submit.

Use these boxes to change your current password. Enter the same word into both boxes and press Submit.

## AEGIS II Browser

### 11 Appendices:

#### a. IO Namespace: Letters & Numbers

The controller uses the letters 'A' to 'Z' to refer to sensors, meters, contact sets & 4-20mA outputs and the numbers '1' to '9' to refer to controls

Users can assign site specific names to all of the I/O, A-Z & 1-9. The I/O letters & numbers are a convenient, compact way to describe both the physical location of the I/O within the controller enclosure & the capabilities of each I/O.

Some letters are 'phantom', meaning they don't have physical wiring location within the enclosure. 'Phantoms' are used to represent calculated & derived values that are logged, alarmed & may be used for control.

| I/O                                    | Type   | Notes   |
|--|--|---|
| <b>A-B</b>                             | Serial sensors   | 3 wire Conductivity-Flowswitch-Temperature or Corrosion Rate or Differential pressure sensors   |
| <b>C-D</b><br><b>E-F</b><br><b>I-J</b> | Dual sensor driver cards<br><br>6 types in any combination | pH-ORP: configurable as dual pH or dual ORP or pH-ORP<br>4-20mA input<br>4-20mA output<br>Conductivity<br>pH & 4-20mA input<br>Dual serial sensor |
| <b>G</b>                               | Built-in 4-20mA input                                      |   |
| <b>H</b>                               | Built-in 10mV/C temperature sensor input                   |   |
| <b>K-N</b>                             | Phantom sensors  | Calculated (Inventory, Manual) or derived from other sensors & meters   |
| <b>O-V</b>                             | Volume meter & contact set inputs                          | Each of 6 inputs configurable as Turbine, Contact Head meter or Contact Set   |
| <b>W-Z</b>                             | Phantom volume meter & contact set inputs                  | Calculated (Fail-to-Feed, Fail-to-Sample) or derived from other sensors & meters  |
| <b>1-2</b>                             | Line powered control relays                                | Form C, powers pumps, solenoids & motorized valves  |
| <b>3-5</b>                             | Dry or line powered control relays                         | Form C, may be used dry or powered.   |
| <b>6-9</b>                             | Pulse or ON/OFF controls                                   | Dry contact sets used to pulse or enable pumps, alarm... 24V 250mA max.   |

## AEGIS II Browser

### b. Input Attributes & Phantoms

Many of the sensors connected to the controller have attributes other than the default value.

For example, the serial conductivity sensor measures conductivity, temperature & includes a flowswitch. The conductivity is the default value of the sensor connect to input 'A' (attribute A0) & the Temperature (attribute A1) & the flowswitch (attribute A2).

Notice that the A1 attribute is of the same type as the A0 attribute, both are sensor values but the A2 attribute is a contact set attribute (ON/OFF).

Attributes can be assigned to phantom inputs where they are logged, alarmed & used for control. A phantom input cannot be assigned to another phantom. (prevents circular references).

Phantoms in the **K-N** space are sensors. Those in the **W-Z** space are volumes & contact sets.

| <b>I/O</b>                             | <b>Type</b>                  | <b>Attribute x = I/O</b>   | <b>Phantom</b>                                       |
|--|------------------------------|--|--|
| <b>A-B</b>                             | Serial Conductivity          | x0 Conductivity<br>x1 Temperature<br>x2 Flowswitch                     | <b>K-N</b><br><b>K-N</b><br><b>W-Z</b>               |
|  | Serial Corrosion Rate        | x0 Corrosion Rate<br>x1 Pitting Rate (Imbalance)                       | <b>K-N</b><br><b>K-N</b>                             |
|  | Serial Differential Pressure | x0 Differential Pressure<br>x1 Inlet Pressure<br>x2 Outlet Pressure    | <b>K-N</b><br><b>K-N</b><br><b>K-N</b>               |
| <b>C-D</b><br><b>E-F</b><br><b>I-J</b> | pH-ORP driver card           | x0 ORP or pH<br>x1 Temperature if pH                                   | <b>K-N</b><br><b>K-N</b>                             |
|  | Conductivity card            | x0 Conductivity<br>x1 Temperature if 'Conductivity'<br>or 'Condensate' | <b>K-N</b><br><b>K-N</b><br><b>K-N</b>               |
|  | pH- 4-20mA input card        | x0 pH<br>x1 Temperature-pH side  | <b>K-N</b><br><b>K-N</b>                             |
|  | Serial Sensor card           | Identical sensors & attributes<br>To <b>A-B</b>                        |  |
| <b>H</b>                               | Temperature                  | x0 Temperature<br>x1 Rate  | <b>K-N</b><br><b>K-N</b>                             |
| <b>O-V</b>                             | Volume meters                | x0 Volume Today<br>x1 Rate<br>x2 Volume this Year<br>x3 Volume total   | <b>W-Z</b><br><b>K-N</b><br><b>W-Z</b><br><b>W-Z</b> |

Use the x0 attribute if you wish to have one sensor display two values.

For example, using a conductivity sensor to measure conductivity & salt concentration

## AEGIS II Browser

### c. 4-20mA Input Selectable Types

Knowing the sensor type connected to a 4-20mA input allows the controller to:

- A. Scale the input correctly for the selected sensor type
- B. Provide calibration & calibration limits appropriate to selected type
- C. Clamp the measured sensor values so that an open loop doesn't measure a negative ppm or conductivity

Select **Sensor Type** = Other if A,B or C not applicable

| <b>Sensor Type</b> | <b>Span Options<br/>&amp; units</b> | <b>mA Span</b> | <b>G=Gain, O=Offset<br/>Span not user modifiable</b>  |
|--------------------|-------------------------------------|----------------|---|
| Other              | Generic 0-100                       | 4-20           | <b>User modifiable span</b><br>G= 6.25, O=-25   |
| CBR Bromine        | CBR 0-2ppm                          | 4-16           | G=0.167, O=-0.667   |
|                    | CBR 0-10ppm                         | 4-16           | G=0.833, O=-3.333   |
| CGE Chlorine       | CGE 0-2 ppm                         | 4-16           | G=0.167, O=-0.667   |
|                    | CGE 0-10ppm                         | 4-16           | G=0.833, O=-3.333   |
| CLE3 Chlorine      | CGE 0-2ppm                          | 4-16           | G=0.167, O=-0.667   |
|                    | CGE 0-10ppm                         | 4-16           | G=0.833, O=-3.333   |
|                    | CGE 0-100ppm                        | 4-16           | G=8.33, O=-33.33  |
| CLO Chlorine       | CLO 0-2ppm                          | 4-16           | G=0.167, O=-0.667   |
|                    | CLO 0-10ppm                         | 4-16           | G=0.833, O=-3.333   |
| CTE Chlorine       | CTE 0-2ppm                          | 4-16           | G=0.167, O=-0.667   |
|                    | CTE 0-10ppm                         | 4-16           | G=0.833, O=-3.333   |
| Diff.Pressure      | DeltaP 0-100psi                     | 4-20           | G= 6.25, O=-25  |
| Fluorescent        | Fluor 0-200ppm                      | 4-20           | G= 12.5, O=-50  |
| PAA 0-200ppm       | PAA 0-200ppm                        | 4-16           | G=16.67, O=-66.67   |
|                    | PAA 0-2000ppm                       | 4-16           | G=166.67, O=-666.67   |
| pH-transducer      | pH 0 to 14                          | 4-20           | 4mA=-1.45pH 20mA=15.45pH<br>pH outside of 0-14 blocked<br>G=1.056, O=-5.674<br>5.373mA=0pH, 18.6mA=14pH |
| ORP-transducer     | ORP 0-1000mV                        | 4-20           | G= 62.5, O=-250   |
| Temperature        | Temp. 0-100C                        | 4-20           | G= 6.25, O=-25  |
| Toroidal           | Tor. 0-10000uS                      | 4-20           | G= 625, O=-2500   |
|                    | Tor. 0-100000uS                     | 4-20           | G= 6250, O=-25000   |

Notes:

1. Gain & Offset return to the table values @ Calibrate = Factory Reset
2. The preceding table applies to the ChemFeed version of the Aegis II



### d. Enabling-Disabling I/O & Adding-Removing Driver Cards

Inputs A-Z cannot be disabled if in use.

The disable option in both the HTTP & local HMIs is replaced with a message telling you where the target sensor is used, so you can remove the dependency.

Note that the sensor can be used for control, compensation of other sensors & in the case of sensors with more than one attribute; as a source for phantom sensors.

When you disable a sensor, the compensation is removed so that if for example:

You disable a thermally compensated conductivity sensor and the thermal sensor is subsequently removed or disabled, there is no conflict when the conductivity sensor is re-enabled, but it's no longer thermally compensated.

When a **C-D**, **E-F** or **I-J** driver card is removed, all of the dependencies are removed on the next power ON. Outputs that use the removed driver sensor(s) for control have the control equation removed. Other sensors which use the removed driver sensors are modified.

When you install a new driver, the sensor inputs default. For example, adding a pH-ORP driver, configures for one pH & one ORP sensor on power ON.

#### **Auto-Removing Phantoms:**

Phantoms are auto-removed if they are derived from inputs  $\geq$  'C'

If the Phantom is in use as an interlock a latching alarm is set.

Example: User removes a serial sensor card with a CTFS sensor OR connects a corrosion rate sensor to a CTFS sensor input on a serial sensor card.

Phantoms derived from inputs 'A' & 'B' are not auto-removed unless the sensor type is changed.

This is done to prevent wholesale auto-reconfiguration & safety related interlock removals on 'A' & 'B' CTFs conductivity sensors.