

0	02/17/06	FIRST ISSUE			GJS			
REV	DATE			BY	APPD	REVD		
REVISIONS								
CUSTOMER PROMINENT FLUID CONTROLS INC.								
(STANDARD SYSTEMS)								
JOB No SS1-PCB1C01111111 PURCHASE ORDE								
SS1-PCB1C01111111 DOSING SKID								
GENERAL ARRANGEMENT								
THIS DRAWING IS THE PROPERTY OF PROMINENT FLUID CONTROLS INC. AND SHALL NOT BE COPIED OR TRANSFERRED WITHOUT THE WRITTEN CONSENT OF PROMINENT FLUID CONTROLS INC.								
ENGINEERS SEAL								
	ProMinent <sup>®</sup> ProMinent GROUP OF COMPANIES							
		PITTS	PITTSBURGH, PA USA		WWW.PROMINENT.US			
		PROMINENT FLUID CONTROLS LTD. 490 SOUTHGATE DRIVE. GUELPH, ONTARIO, CANADA N1H 6J3 TEL. 519 836 5692 FAX. 519 836 5226		PROMINENT FLUID CONTROLS INC. RIDC PARK WEST 136 INDUSTRY DRIVE, PITTSBURGH P.A., USA. 15275 TEL. 412 787 2484 FAX. 412 787 0704				
		DESIGNED	GJS	APPROVED				
		DRAWN	GJS	SCALE N.T.S.				
		CHECKED	JMS	DATE 02/17/06				
DWG № SS1-PCB1C01111111-200				REV 0	/	PAGI 1/1	-	

2. DIMENSIONS TO BE HELD WITHIN +\-1/4" [+/-6MM].

COMPONENTS.

1. ALL PIPING AND FITTINGS SHALL BE 1/2" SCH. 80 PVC SOCKET WELD WITH VITON SEALS UNLESS OTHERWISE REQUIRED BY

NOTES: